



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F.6/DFS/MS/School/2025/SZ/ 166

Dated: 21/03/2025

To

The Head of School,  
GSR Sarvodaya Kanya Vidyalaya,  
C - Block, Defence Colony, New Delhi-110024

**Sub: Inspection report in r/o Georgi Stoikov Rakovski Sarvodaya Kanya Vidyalaya located at C-Block, Defence Colony, New Delhi-110024 (School ID: 1924023)**

Sir,

Please refer to your letter No. Nil dated 16.01.2025 received through outdoor diary No. 11510 dated 17/01/2025. In this connection, it is to inform you that the premise was inspected by the officer concerned of this department from fire safety point of view on dated 15/03/2025 in the presence of Sh. Dalbir Singh (Estate Manager). During course of inspection, the shortcomings observed are as below.

1. The hose-reel hose found non-functional, nozzle missing.
2. Terrace level fire pump was not on auto mode.

In view of above, application for renewal of fire safety certificate cannot be considered at this stage. You are requested to rectify the shortcomings above, under intimation to this department for further action in the matter.

Yours faithfully,

(ATUL GARG)

Director

T. No. 011-23414000

01/03/25

Copy to: -

1. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054.