



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. 6/DFS/MS/GH/NDZ/2025/42

Dated 23/01/2025

To,

The Joint Commissioner of Police (Lic.),  
1<sup>st</sup> floor, Police Station Defence Colony,  
New Delhi – 110024.

**Subject: - Regarding grant of Fire Safety Certificate in r/o Guest House Building at Plot No. 298, Block-A-1, Janakpuri, New Delhi-110058.**

Sir,

This has a reference to MHA application No. 2025010700249 dated 07/01/2025, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officer concerned of this department on 13/01/2025 in the presence of Mr. Amandeep (Owner) and observed that building comprised of Basement (Dinning hall), Stilt (Office& reception), Ground, 1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup> floor each having 09 guest rooms respectively (Total 36 guest rooms only).

**Following shortcomings were observed during time of inspection:**

1. Dinning hall running in basement instead of storage should be removed.
2. Stilt being used as reception & office instead of parking.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)  
DIRECTOR

o/c DELHI FIRE SERVICE

**Copy to:-**

1. Mr. Amandeep (Owner), Guest House Building, Plot No. 298, Block-A-1, Janakpuri, New Delhi-110058.