



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

c/37



No. F.6/DFS/MS/School/2025/WZ/ 378

Dated: 13/05/2025

To,

The Principal,
Gian Deep Model School,
Kh. No. 50/2, Village Nizampur,
Delhi-110081.

Sub:- Renewal of Fire Safety Certificate in respect of Gian Deep Model School located at Kh.No. 50/2, Village Nizampur, Delhi- 110081.

Sir,

This has reference to your letter no. nil received through outdoor diary no. 15100 dated 28/03/2025, on the subject cited above. In this connection it is informed that above mentioned school building was visited by the officer concerned of this department on 02.05.2025 to see the compliance of requisite fire safety measures. Sh. Faturi Prasad (Principal) was present at the time of inspection.

During the course of inspection it was observed that the school building is comprised of Ground plus First floor. Following shortcomings were observed at the time of inspection:-

1. Width of staircase found 0.90 m to 1.40 m & 0.80 m against the required width of 1.5 m & 1 m.
2. Width of corridor at First floor found 0.80 m against the required width of 1.5 m.
3. P.A. system not provided.
3. Fire extinguishers found provided but not functional.
4. Exit signage's found removed.

You are advised to rectify the above-mentioned shortcomings under intimation to this department.

Yours Faithfully

(Atul Garg)
Director

Ph. 011-23414000

Copy to:-

1. Director of Education, Govt. Of NCT of Delhi, Old Secretariat, New Delhi.