



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001



No. F6/DFS/MS/2025/WZ/School/ 1164

Dated: 22/09/2025

FIRE SAFETY CERTIFICATE

Certified that the G. N. Public School, A-97, Raj Park, S.P. Road, Delhi-110086, comprised of Ground + 02 upper floors has already been issued FSC by this department vide letter No. F.6/DFS/MS/2022/WZ/School/942 dated 01.09.2022. The premises was re-inspected by the officer concerned of this department on 02.09.2025 in the presence of Mrs. Babita (Principal) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises fit for occupancy class Educational "Group B" with effect from 22/09/2025 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subjected to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 22/09/2025 at New Delhi by


(Virendra Singh)
Chief Fire Officer
Delhi Fire Service

Copy to :-

1. The Director of Education, Old Secretariat, Delhi.
2. The Principal, G. N. Public School, A-97, Raj Park, S.P. Road, Delhi-110086.

Conditions for the validity of fire safety certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on
8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/
http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms

INSPECTION REPORT

1. Name & address of the building : G. N. Public School, A-97, Raj Park, S.P. Road, Delhi-110086.
2. Type of Occupancy : Educational
3. Type of Case : Renewal (**Ground + 02 upper floors**)
4. Details of Previous NOC : F.6/DFS/MS/2022/WZ/School/942 dated 01.09.20.
5. Fire Safety directives letter No : NBC Part-IV.
6. Date of inspection : 02.09.2025.
7. Name of Inspecting Officer : A.K.Sharma ADO(Rohini)
8. Name and designation of officers
From the building side : Mrs. Babita (Principal)
9. Year of Construction : 2009
10. Applicant's letter No. : Online e-mail dated 22.08.2025.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> Road width 	Accessible	Accessible	MR
	<ul style="list-style-type: none"> Gate width 	Directly accessible	Directly accessible	MR
	<ul style="list-style-type: none"> Width of internal road 	-NA-	-NA-	-NA-
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> Upper Floors 	01nos.	01nos.	MR
	<ul style="list-style-type: none"> Basements 	-NA-	-NA-	-NA-
	b. Width of staircases			
	<ul style="list-style-type: none"> Upper Floor 	1.5m	1.5m	MR
	<ul style="list-style-type: none"> Basements 	-NA-	-NA-	-NA-
	c. Protection of exits			
	Fire check door			
	<ul style="list-style-type: none"> Pressurization 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
	d. No. of continuous staircases to terrace	-NA-	-NA-	-NA-
	e. Width of Corridor	-NA-	-NA-	-NA-
	f. Door Size	1.0m	1.0m	MR
3.	Compartmentation			
	<ul style="list-style-type: none"> Fire check door 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Sealing of electrical shafts 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Fire Rating of shaft door 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Water Curtain 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Fire Dampers 	-NA-	-NA-	-NA-
4.	Smoke Management System			
	<ul style="list-style-type: none"> Basements 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Upper floors 	12 a/c per hour	Natural ventilated	MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers 	03nos.	04nos.	MR
	<ul style="list-style-type: none"> Types 	ABC/CO2	ABC-04	MR
	<ul style="list-style-type: none"> IS marking 	ISI marked	Yes	MR
6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor 	01nos.	Provided	MR
	<ul style="list-style-type: none"> Length of hose reel hose 	30mm	Provided	MR
	<ul style="list-style-type: none"> Nozzle diameter 	5m	Provided	MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Location of Main Panel 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Location of Repeater Panel 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Alternate source of power 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Hooters' Location 	-NA-	-NA-	-NA-

8.	MOEFA	-NA-	-NA-	-NA-
9.	Public Address System	-NA-	-NA-	-NA-
10.	Automatic Sprinkler System			
	• Basement	-NA-	-NA-	-NA-
	• Ground & Upper Floors	-NA-	-NA-	-NA-
	• Sprinkler above false ceiling	-NA-	-NA-	-NA-
11.	Internal Hydrants			
	• Size of riser/down-comer	-NA-	-NA-	-NA-
	• Number of hydrants per floor	-NA-	-NA-	-NA-
	• Hose Box	-NA-	-NA-	-NA-
12.	Yard Hydrants			
	• Total number of hydrants	-NA-	-NA-	-NA-
	• Hose Box	-NA-	-NA-	-NA-
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main Pump	-NA-	-NA-	-NA-
	➤ Head of Main pump	-NA-	-NA-	-NA-
	➤ Number of main pumps	-NA-	-NA-	-NA-
	➤ Jockey Pump out put	-NA-	-NA-	-NA-
	➤ Jockey pump head	-NA-	-NA-	-NA-
	➤ Standby Pump out put	-NA-	-NA-	-NA-
	➤ Standby Pump Head	-NA-	-NA-	-NA-
	➤ Auto Starting/Manual Stopping	-NA-	-NA-	-NA-
	➤ Pump House Access	-NA-	-NA-	-NA-
	• Terrace level			
	➤ Discharge of pump	450lpm	450lpm	MR
	➤ Head of the pump	40m	40m	MR
	➤ Power Supply	-NA-	-NA-	-NA-
	➤ Auto Starting of pump	-NA-	-NA-	-NA-
14.	Captive Water Storage for fire fighting			
	• Underground tank capacity	-NA-	-NA-	-NA-
	➤ Draw-off connection	-NA-	-NA-	-NA-
	➤ Fire service inlet	-NA-	-NA-	-NA-
	➤ Access to tank	-NA-	-NA-	-NA-
	• Overhead Tank capacity	10,000ltr	10,000ltr	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	• Pressurization of Lift Shaft	-NA-	-NA-	-NA-
	• Pressurization of Lift lobby	-NA-	-NA-	-NA-
	• Communication In lift Car	-NA-	-NA-	-NA-
	• Fireman's Grounding Switch	-NA-	-NA-	-NA-
	• Lift Signage	-NA-	-NA-	-NA-
17.	Standby power supply	-NA-	-NA-	-NA-
18.	Refuge Area.			
	➤ Total Area	-NA-	-NA-	-NA-
	➤ Location	-NA-	-NA-	-NA-
19.	Fire Control Room			
	• Detector System Panel	-NA-	-NA-	-NA-
	• Flow Switch Panel	-NA-	-NA-	-NA-
	• PA System Panel	-NA-	-NA-	-NA-
	• Battery backup	-NA-	-NA-	-NA-
	• Building Floor Plans	-NA-	-NA-	-NA-

N/26


Special Fire Protection System for
Protection of special Risks, if any:

-NA-

-NA-

-NA-

Accordingly, the fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.
In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the FSC issued vide letter no. **F.6/DFS/MS/2022/WZ/School/942 dated 01.09.2022** is **recommended for renewal** of FSC under rule 37 of the Delhi Fire Service rules 2010.


Signature of the Inspecting Officer
Name **Ajay Kumar Sharma**
Designation **ADO(Rohini)**

DO (NW) N/A


Dy. Chief Fire Officer (WZ)

DCFO/...SOS...N/A

Dated...08/09/25


8/9

CFO/


9/9/2025

CFO to Same.

Principal Director



12/09/25

CFO/




15/9/25

ADO (Rohini)

FT letter is put up for kind
perusal and signature please.


18/9/25

CFO/ 
19/9/2025

my