

24



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001**

No F 6/DFS/MS/EH/2025/WZ/ 160

Dated: 30/04/2025

**FIRE SAFETY CERTIFICATE**

Certified that the M/s Gola Sizzlers Pvt. Ltd. located at Shop No. SF/2F/14A, 2<sup>nd</sup> Floor, Pacific Mall, Subhash Nagar, New Delhi-110018 in a building comprised of **Two Basements, Ground and Four upper floors plus projection room** was issued FSC by this department vide letter No F6/DFS/MS/EH/MN/2022/168 dated 09.06.2022. The premise was re-inspected by the officer concerned of this department on 17.04.2025 in the presence of **Sh. N.P. Sharma (Manager)** and observed that all the fire prevention and fire safety arrangements as provided in the premises found in good working condition. The premises have therefore complied with fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building/ premise is fit for occupancy "**Assembly (Group D)**" with effect from 30/04/2025 for a period of three years in accordance with the Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40, subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 30/04/2025 at New Delhi, by

  
( Atul Garg )  
Director

Delhi Fire Service

Copy to: -

1. Owner/ occupier, M/s Gola Sizzlers Pvt. Ltd. located at Shop No. SF/2F/14A, 2<sup>nd</sup> floor, Pacific Mall, Subhash Nagar, New Delhi-110018.
2. The Dy. Health Officer, MCD, West Zone, Vishal Enclave, Rajauri Garden, New Delhi-110027.
3. MCD Portal, ID No. 2025040505699.

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate through MHA portal (<https://www.mcdonline.nic.in>) along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
8. The basement shall be used as per BBL.

## INSPECTION REPORT

Name & address of the building : M/s Gola Sizzlers Pvt. Ltd. located at SF/2F/ 14 A Second Floor, Pacific Mall, Subhash Nagar, New Delhi-110018.

Type of Occupancy : Assembly (Restaurant) at Second Floor.

Type of Case : Renewal

Details of Previous NOC : F6/DFS/MS/EH/MN/2022/168 Dated 09/06/2022

Fire Safety directives letter No : Nil

Date of inspection : 17/04/2025

Name of Inspecting Officer : R.K.Sinha, ADO (BW)

Name and designation of officers : Sh. N.P. Sharma (Manager)

From the building side : 2009 as per MCD Portal

Year of Construction : MCD Application ID No. 2025040505699 dated 06/04/2025

Applicant's letter No. : The said restaurant is running at 2<sup>nd</sup> floor in Pacific Mall, Subhash Nagar in a building comprised of two basements, ground and four upper floors & projection room was issued FSC vide letter no. F6/DFS/MS/WZ/Mall/2023/349 dated 21/07/2023.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	As per inspection report dated 03/06/2022	Provided at site	Remarks MR/NMR
1.	<b>Access to building</b>			
	Road width	12 m	Provided	MR
	Gate width	5 m	Provided	MR
	Width of internal road	6 m	Provided	MR
2.	<b>Number, Width, Type &amp; Arrangement of Exits Common with mall</b>			
	<b>a. Number of staircases</b>			
	Upper Floors	02	Provided by mall	MR
	Basements	NA	NA	NA
	<b>b. Width of staircases</b>			
	Upper Floor	1.5 m	Provided by mall	MR
	Basements	NA	NA	NA
	<b>c. Protection of exits</b>			
	Fire check door	NA	NA	NA
	Pressurization	NA	NA	NA
	<b>d. No. of continuous staircases to terrace</b>			
		NA	NA	NA
	<b>e. Width of Corridor</b>			
		NA	NA	NA
	<b>f. Door Size</b>			
		1.5 m × 2	Provided	MR
3.	<b>Compartmentation</b>			
	Fire check door	NA	NA	NA
	Sealing of electrical shafts	NA	NA	NA
	Fire Rating of shaft door	NA	NA	NA
	Water Curtain	NA	NA	NA
	Fire Dampers	NA	NA	NA
4.	<b>Smoke Management System</b>			
	Basements	NA	NA	NA
	Ground floor	Required	Provided	MR
5.	<b>Fire Extinguishers</b>			
	Total numbers	04 Nos.	Provided	MR
	Types	ABC/Co2 Type	Provided	MR
	IS marking	Required	Provided	MR
6.	<b>First-Aid Hose Reels Common with mall</b>			
	Total numbers on each floor	01	Provided	MR
	Length of hose reel hose	30 m	Provided	MR
	Nozzle diameter	5 mm	Provided	MR
7.	<b>Automatic fire detection and alarming system</b>			
	Type of detectors	Smoke	Provided	MR
	Location of Main Panel	Required	Provided	MR
	Location of Repeater Panel	NA	NA	NA
	Alternate source of power	Required	Provided	MR
	Hooters' Location	Required	Provided	MR



8.	MOEFA	Required	Provided	MR
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	Basement	NA	Provided	NA
	Upper Floor	Required	Provided	MR
	Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants	Common with mall		
	Size of riser/down-comer	150 mm	Provided	MR
	Number of hydrants per floor	02	Provided	MR
	Hose Box	02	Provided	MR
12.	Yard Hydrants			
	Total number of hydrants	NA	NA	NA
	Hose Box	NA	NA	NA
13.	Pumping Arrangements	Common with mall		
	Ground Level			
	Discharge of main Pump	NA	Common with mall	NA
	Head of Main pump	NA	Common with mall	NA
	Number of main pumps	NA	Common with mall	NA
	Jockey Pump out put	NA	Common with mall	NA
	Jockey pump head	NA	Common with mall	NA
	Standby Pump out put	NA	Common with mall	NA
	Standby Pump Head	NA	Common with mall	NA
	Auto Starting/Manual Stopping	NA	Common with mall	NA
	Pump House Access	NA	Common with mall	NA
	Terrace level			
	Discharge of pump	900 lpm	Common with mall	MR
	Head of the pump	40 m	Common with mall	MR
	Power Supply	Required	Common with mall	MR
	Auto Starting of pump	Required	Common with mall	MR
14.	Captive Water Storage for fire fighting	Common with mall		
	Underground tank capacity	NA	200,000 ltrs	NA
	Draw-off connection	NA	Provided	NA
	Fire service inlet	Required	Provided	MR
	Access to tank	Required	Provided	MR
	Overhead Tank capacity	20,000 ltrs	Provided	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	Pressurization of Lift Shaft	NA	NA	NA
	Pressurization of Lift lobby	NA	NA	NA
	Communication In lift Car	NA	NA	NA
	Fireman's Grounding Switch	NA	NA	NA
	Lift Signage	NA	NA	NA
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area.			
	Total Area	NA	NA	NA
	Location	NA	NA	NA
19.	Fire Control Room			
	Detector System Panel	NA	NA	NA
	Flow Switch Panel	NA	NA	NA
	PA System Panel	NA	NA	NA
	Battery backup	NA	NA	NA
	Building Floor Plans	NA	NA	NA

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.  
Keeping in view of compliance of the minimum standards of fire prevention and fire safety measures as required under rules it is recommended to renew the fire safety certificate issued vide letter no. F6/DFS/MS/EH/MN/2022/168 dated 09/06/2022 under Rule 37 of the Delhi Fire Service Rules, 2010.

Signature of Inspecting Officer  
Name : Rajeev Kumar Sinha  
Designation : ADO/B.W.

21/4/25

Dr (F6/22)

DCFO/6/9-MNA

Dated 22/04/25

22/4/2025

CFO  
26/4/2025

Director  
29/4/25

Ms/BW  
fsc please uploaded

30/4/25

ms (ell)

Uploaded  
01/5/25

Q