



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/GH/2025/SZ/ 199

Dated: 25/04/2025

To

The Joint Commissioner of Police (Lic.),
1st Floor, P.S. Defense Colony
New Delhi-110049

Sub: Inspection report in r/o M/s Golden Deluxe Guest House situated at Prop. No. 14A/7, WEA, Karol Bagh, New Delhi-110005

Sir,

Please refer to online (etl.mcdonline.nic.in) application Id. 2025032504527 dated 07/04/2025. In this connection, it is to inform you that the said premise was inspected by the officer concerned of this department from fire safety point of view on dated 18/04/2025 in the presence of Sh. Satpal Katyal (Partner). During course of inspection, the shortcomings observed are as below.

1. Terrace level fire pump found not automatic in operation.
2. Basement floor used for commercial activities, same needs verification and approval from building sanctioning authority.

In view of the above, the application for issuance of fire safety certificate is rejected. The occupancy of the premises in the absence of requisite fire safety certificate/arrangements shall be at the risk and liability of the owner/occupier. The local/licensing authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)
DIRECTOR

Ph. 011-23414000

Copy to: -

1. Sh. Hemant Puri M/s Golden Deluxe Guest House situated at Prop. No. 14A/7, WEA, Karol Bagh, New Delhi-110005