



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75
आज़ादी का
अमृत महोत्सव

No. F6/DFS/MS/GH/SZ/2025/ 112

Dated: 07/03/2025

To

The Joint Commissioner of Police,
Office of Joint Commissioner of Police: Licensing,
1st Floor, P. S Defence Colony, New Delhi.

Sub: -Regarding grant of Fire Safety Certificate in r/o M/s Golden Keys Inn located at B-2/15, Ambedkar Chowk, Ashok Vihar, Phase-II, Delhi-52.

Sir,

With reference to the etl.mcdonline application no. 2024090513782 on the subject cited above, it is informed that the said Guest house was inspected officer concerned from this department on 03.03.2025 in the presence of Mr. Shankar (Duty Manager) and it was observed that the Guest house is running at 1st to 3rd floor of the building which is comprised of Basement + Stilt + Upper Ground + 03 upper floors. During the inspection following shortcomings were observed:

1. The staircase at stilt floor must be segregated by means of Fire Check Door (FCD).
2. CO detector found not provided.
3. Overhand tank capacity of 15,000 liters for firefighting found not provided.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Arul Garg)
Director

Delhi Fire Service

04/3

07/03