



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

आजादी का
अमृत महोत्सव

No. F6/DFS/MS/School/NDZ/2025/ 250

Dated: 17/04/2025

To,

The Principal,
Golden Public School
Street No. 16, Rajiv Gandhi Nagar,
New Mustafabad, Delhi – 110094

Subject: - Regarding grant of Fire Safety Certificate in r/o Golden Public School located at Street No. 16, Rajiv Gandhi Nagar, New Mustafabad, Delhi – 110094.

Sir,

This has a reference to your Outdoor diary no. 12693 dated 20/02/2025, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officer concerned of this department on 07/04/2025 in the presence of Mrs. Husan Ara Begum (Principal) and observed that building comprised of ground plus two upper floors. Earlier building was ground plus first floor only.

Following shortcomings were observed during time of inspection:

1. One staircase of width 1.20 meter is provided against requirement of 02 nos. of staircase width 1.50 meter each.
2. Width of corridor 1.20 meter provided against requirement of 1.50 meter.
3. Door size of 0.85 meter provided against requirement of 1.20 meter.
4. 04 nos. of fire extinguisher provided against requirement of 08 nos.
5. First-Aid-Hose Reel found removed.
6. Terrace level fire pump capacity of 450 LPM not provided.
7. Overhead tank of capacity 10,000 liters not provided.
8. Exit & floors Signage's not provided at strategic location in the building.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE

Copy to:-

1. The Director of Education, East Delhi Municipal Corporation, 419, Udyog Sadan, Patparganj Industrial Area, Delhi - 110092.