



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**

75  
आज़ादी का  
अमृत महोत्सव

No. F.6/DFS /MS/2023/ 178

Dated: 18 / 08 /2023

To

The Chief Architect,  
NDMC Head Office,  
Palika Kendra, Parliament Street,  
New Delhi-110001.

**Sub:** Examination of building plans from fire safety point of view in r/o proposed construction of Gole Market Musuem, New Delhi-110001.

Please refer your request ID: 0085 dated 01/08/2023 on the subject cited above. In this connection this is to inform you that the referred online building plans in respect of proposed construction of Gole Market Musuem New Delhi-110001 has been scrutinized by this department from fire and life safety point of view and observed that the proposed building is comprised of ground floor and one upper floor having height 11.75 mtrs.

Following shortcomings are observed: -

1. The width of the staircase is not as per clause 7.11.1 (b) of UBBL 2016.
2. Drawings are not submitted in according to clause 2.0.4 of UBBL-2016.
3. Details of staircase w.r.t. (width, tread and riser) are not shown on the plans as per clause 8.4.3 / 7.11 of UBBL 2016.
4. Entry to the staircase is not proposed through fire check doors as per NBC part IV 2016.
5. Doors and windows schedule is not provided.
6. Fire and life safety arrangements are not proposed as per part 4 NBC 2016.

In view of the above, the building plans are rejected.

Yours faithfully,

  
(ATUL GARG)  
DIRECTOR  
Delhi Fire Service  
overlax 25