

C/66

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

No.F6/DFS/MS/GH/NDZ/ 382

Dated: 10/09/2025

To,

The Commissioner, MCD,
Civic Centre, New Delhi.

Sub: Issuance of FSC (Fire Safety Certificate) in r/o M/S Gold INN (MG Sons Landholdings LLP) 12A/24, W.E.A Saraswati Marg, Karol Bagh, Delhi.

Sir,

This has reference to on line ID No. 2025081812578 dated 21.08.2025, on the subject cited above. In this regard, it is to inform you that the site was inspected by the officers concerned of this department on 27/08/2025 in the presence of Mr. Shymal and following shortcomings were observed: -

1. PA system found removed.
2. MOEFA found non functional.
3. CO detector found non functional.
4. Further, basement was not checked as the same was found locked.

In view of above shortcomings the case is rejected and Fire Safety Certificate (FSC) cannot be issued due to above shortcomings. Therefore, you are requested to direct the applicant to rectify the above shortcomings and re-submit for further consideration in the matter.

Yours faithfully


(Virendra Singh)
Chief Fire Officer

Copy to :

1. The DHO/MHO, MCD (Public Health), 19th floor , Civic Centre, New Delhi.
2. The Manager, Gold INN (MG Sons Landholdings LLP) 12A/24, W.E.A Saraswati Marg, Karol Bagh, Delhi.