



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75
आज़ादी का
अमृत महोत्सव

No. F6/DFS/MS/School/WZ/2025/ 1159

Dated:- 18/09/2025

FIRE SAFETY CERTIFICATE

Certified that the Govt. Co-Ed. Sarvodaya Vidyalaya (School ID-1413003), Located at Ghevra, Delhi-110081, comprised of Ground + 03 Upper Floors & M.P. Hall, owned/occupied by Govt. Co-Ed. Sarvodaya Vidyalaya (School ID-1413003), was issued Fire Safety Certificate by this department Vide Letter No. F6/DFS/MS/School/WZ/2022/1169 dated 20/10/2022. The said premise was re-inspected by the officer concerned of this department on 28/08/2025 in the presence of Sh. Jasbir Singh (Estate Manager) and found that the premises/building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of Delhi Fire Service Rules, 2010 and that the premises/building is fit for occupancy class "Educational Building" Group B with effect from 18/09/2025 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on ...18/09/2025 at New Delhi by.


17/9/2025
Virendra Singh
Chief Fire Officer

Copy to:-

1. The Director, Directorate of Education, GNCT of Delhi, Old Secretariat Delhi – 110054
2. The Principal, Govt. Co-Ed. Sarvodaya Vidyalaya (School ID-1413003), Ghevra, Delhi-110081.

Conditions for validity of fire safety certificate:-

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37) along with copy of the certificate, six months prior to its expiry.

INSPECTION REPORT

1. Name & address of the building : Govt. Co-ed. Sarvodaya Vidyalaya (School ID-1413003) Located at Ghevra, Delhi-110081
2. Type of Occupancy : Educational,
3. Type of Case : Renewal, (G + 03 Upper Floor & M.P. Hall)
4. Details of previous NOC : F6/DFS/MS/School/WZ/2022/1169 dated 20/10/2022
5. Fire Safety directives Letter No. : as per NBC Part-IV
6. Date of inspection : 28/08/2025
7. Name of the Inspecting Officer : Aman Kumar Lathar, ADO (JWP)
8. Name and designation of Officer
from the building side : Sh. Jasbir Singh (Estate Manager)
9. Year of Construction : 2021-22
10. Applicant's letter No. : SVG/2025/520 dated 22/07/2025

S No	Minimum standards on fire prevention and fire safety U/R 33	NBC Requirement/as per earlier FSC issued dated 20/10/2022	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	06 m	Provided	MR
	• Gate width	4.5 m	Provided	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	04	04 & 01 ramp	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1.5 m each	1.70 m x 3, 1.64 m x 1 & 2 m to 1.64 m x 1 ramp	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	02	04	MR
	e. Width Of Corridor	1.5 mtrs.	Provided	MR
	f. Door Size	1.2 mtrs.	Provided	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA
5.	Fire Extinguishers			
	• Total numbers	34 nos.	Provided	MR
	• Types	ABC & CO ₂	Provided	MR
	• ISI marking	ISI Marked.	Provided	MR

6.	First – Aid Hose Reels			
	• Total numbers on each floor	02	05	MR
	• Length of hose reel hose	30m	Provided	MR
	• Nozzle diameter	5mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants:			
	• Size of riser/down- comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements:			
	• Ground Level			
	• Discharge of main pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Staring/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	450 lpm	450 lpm x 2	MR
	➤ Head of the pump	40Mtr	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for fire fighting:			
	• Under ground tank capacity	NA	NA	NA
	➤ Draw off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	10,000Ltrs.	Provided.	MR
15.	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA

20.	Special Fire Protection Systems for Protection of special Risks, if any;	Required	ABC type fire ext. for electrical panel	MR
-----	--	----------	---	----

The fire protection systems provided in the building were checked and found functional at the time of inspection.

Note: - Management has constructed a separate M. P. Hall, have provided 06 nos. exit doors (2 m x 1, 1.5 m x 1 & 1.25 m x 3 wide) & protected with 02 nos. hose reels & hydrant.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety requirements under the rules, **renewal of Fire Safety Certificate issued** vide letter no. F6/DFS/MS/School/WZ/2022/1169 dated 20/10/2022 is **recommended** under Rule 37 of the Delhi Fire Service Rules, 2010 under DFS Act 2007.

Accordingly DFA is put up for approval please.

[Signature]
29/10/25
Aman Kumar Lathar
ADO (JWP)

[Signature]
29/10/25

[Signature]
29/10/25

4/11/25
19/10/25

CFO/
[Signature]
6/11/2025

Principal Director

CFO to Secy.

[Signature]
12/09/25

[Signature]

[Signature]
15/11/2025

ADO (JWP)

Sir, F.S. letter is put-up for your signature pl.

CFO/
[Signature]
17/11/2025

[Signature]
16/10/25
ADO (JWP)

MS