



e 37



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No. F6/DFS/MS/EH/SZ/2026/ 456

Dated: 08/05/2026

FIRE SAFETY CERTIFICATE

Certified that the M/s Govardhan Motels & Restaurant at Plot No 84, Ground & first Floor, Sri Aurobindo Marg, Adhchini, New Delhi-110017. Owned/Occupier by M/s Govardhan Motels & Restaurant, have complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of this department on 27/04/2026 in the presence of Sh. Varun Gupta and the premise is fit for occupancy "Assembly Building" (Group-D) (Restaurant at Ground and First Floor Only) with effect from 08/05/2026 for a period of 03 Three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010. Conditions mentioned below.

Issued on08/05/2026 at New Delhi by


(A.K. Malik)
Chief Fire Officer

Copy to:

1. The Commissioner MCD, Civic Centre, Minto Road, New Delhi- 110002. - to ensure the occupancy as detailed above & deviation if any
2. M/s Govardhan Motels & Restaurant at Plot No 84, GF & FF, Sri Aurobindo Marg, Adhchini, New Delhi-110017. (Online application ID No. - 2026040804566 dated-14/04/2026)

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non-functional fire safety measure shall be at the responsibility of the management/occupier.
3. The trained firefighting staff should be available round the clock.
4. Any deviation with regard to the construction etc. shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

INSPECTION REPORT

1. Name & address of the building	M/s Govardhan Motels & Restaurant at Plot No 84, GF & FF, Sri Aurobindo Marg, Adhchini, New Delhi-110017.
2. Type of Occupancy	Group-D (Assembly Building) (restaurant running at ground and first floor only)
3. Building comprised of	Ground and One Upper Floors
4. Type of Case	New
5. Details of Previous NOC	Nil
6. Fire Safety directives letter No	Nil
7. Date of inspection	27/04/2026
8. Name of Inspecting Officer	Sh. Sarabjeet Singh ADO (BCP)
9. Name and designation of officers From the building side	Sh. Varun Gupta
10. Year of Construction	1995
11. Applicant's letter No.	Online-ID No – 2026040804566 dated-14/04/2026

S. No	Minimum Standards on fire prevention and fire safety U/R 33	UBBL/NBC	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	06m	Provided	MR
	• Gate width	NA	NA	NA
	• Width of internal road	NA	NA	NA
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	02 Nos.	03 Nos.	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floor	1.50m each	1.25m(G. to FF), 1.5m & 1.60m	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	02 Required	Provided	MR
	e. Width of Corridor	NA	NA	NA
	f. Door Size	2X1.50m	2 x 1.50m Provided	MR
3.	Compartmentation			
	a) Fire check door	Required	Provided	MR
	b) Sealing of electrical shafts	NA	NA	NA
	c) Fire Rating of shaft door	NA	NA	NA
	d) Water Curtain	NA	NA	NA
	e) Fire Dampers	NA	NA	NA
4.	Smoke Management System			
	a) Basements	NA	NA	NA
	b) Upper floors	NA	NA	NA
5.	Fire Extinguishers			
	a) Total numbers	06 Nos	Provided	MR
	b) Types	ABC/CO ₂	ABC-04/CO ₂ -02	MR
	c) IS marking	ISI marked	Provided	MR
6.	First-Aid Hose Reels			
	a) Total numbers on each floor	01	Provided	MR
	b) Length of hose reel hose	30mm	Provided	MR
	c) Nozzle diameter	5m	Provided	MR

7.	Automatic fire detection and alarming system			
	a) Type of detectors	NA	NA	NA
	b) Location of Main Panel	NA	NA	NA
	c) Location of Repeater Panel	NA	NA	NA
	d) Alternate source of power	NA	NA	NA
	e) Hooters' Location	NA	NA	NA
8.	MOEFA	Required	Provided	MR
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	a) Basement	NA	NA	NA
	b) Ground & Upper Floors	NA	NA	NA
	c) Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants			
	a) Size of riser/down-comer	100 m	Provided	MR
	b) Number of hydrants per floor	01	Provided	MR
	c) Hose Box	01	Provided	MR
12.	Yard Hydrants			
	a) Total number of hydrants	NA	NA	NA
	b) Hose Box	NA	NA	NA
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main Pump	NA	NA	NA
	➤ Head of Main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey Pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/Manual Stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	Terrace level			
	➤ Discharge of pump	450 LPM	Provided	MR
	➤ Head of the pump	40 m	Provided	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14.	Captive Water Storage for fire fighting			
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	20,000 ltrs	20,000ltrs, Provided	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of Lift Shaft	NA	NA	NA
	b) Pressurization of Lift lobby	NA	NA	NA
	c) Communication In lift Car	NA	NA	NA
	d) Fireman's Grounding Switch	NA	NA	NA
	e) Lift Signage	NA	NA	NA

17.	Standby power supply	NA	NA	NA
18.	Refuge Area.			
	a) Total Area	NA	NA	NA
	b) Location	NA	NA	NA
19.	Fire Control Room			
	a) Detector System Panel	NA	NA	NA
	b) Flow Switch Panel	NA	NA	NA
	c) PA System Panel	NA	NA	NA
	d) Battery backup	NA	NA	NA
	e) Building Floor Plans	NA	NA	NA
20.	Special Fire Protection System for Protection of special Risks, if any:	NA	NA	NA

* Earlier shortcomings issued by this department vide letter No. F.6/DFS/MSEH/2024/SZ/352 dated 27/08/2024 have been rectified.


The fire protection systems provided in the building were checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rule 2010 is recommended. Accordingly, FSC is put up for approval and signatures please.

Last date of Disposal- 11/05/2026

Signature of the Inspecting Officer
Name - Sarabjeet Singh
Designation - ADO(BCP)

DO (SD) 
30/4/26


A.K. MALIK
4/5/26

Principal Director

FO to Secy.

FO (SX)


04/05/26


A.K. MALIK
5/5/26

Ravinder Singh