

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001**


No.F6/DFS/MS/2025/ School/ 1248

Dated: 13/10./2025

**FIRE SAFETY CERTIFICATE**

Certified that the Govt. Boys Sr. Sec. School, Shadi Khampur, New Delhi. comprises of Gr. + 03 Upper floor & hall at ground floor. The site was inspected by the officer concerned of this department on 29/09/25 in the presence of Mr. Dheeraj, IT Assistant and found that school has complied with the fire prevention and fire safety requirements in accordance with Circular No. F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01/03/2011 issued by Director of Education and the building premises is fit for occupancy of class Sub-Div. B-I Group B "Educational Building" with effect from ...13/10/2025... for a period of **three years** subject to compliance of the conditions mentioned below:

Issued on ...13/10/2025... at New Delhi by.

  
(A.K. Malik)  
Dy. Chief Fire Officer  
South Zone

**Copy to:-**

1. The Commissioner, MCD Civic Center, New Delhi.
2. Director of Education, Govt. of NCT, Delhi.
3. The Principal, Govt. Boys Sr. Sec. School, Shadi Khampur, New Delhi.

**Condition for the validity of fire safety certificate**

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. The compliance with regards to electrical installation, structural stability, set back area, occupancy and any deviation in construction etc. shall be verified from authority concerned.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry".

N/26

## INSPECTION REPORT

1. Name & address of the building:- Govt. Boys Sr. Sec. School, Shadi Khampur, New Delhi.
2. Type of occupancy:- Educational Group-B  
Educational Building Gr. + 03 Upper floor & hall at ground floor.
3. Type of case:- fresh
4. Details of previous FSC:- N/A
5. Fire safety directives No.- N/A
6. Date of inspection:- 29/09/25
7. Name of the inspecting officer:- Sh. Ravinder Singh (DO)
8. Name & designation of officer  
From the building side:- Mr. Dheeraj, IT assistant
9. Year of construction:- 2022
10. Applicant's letter No:- letter no. GBSSS/SKP/2025/663 dated 02.09.2025

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirements 01.03.2011	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	06 mtr.	Provided	MR
	2) Gate width	NA	NA	NA
	3) Width of internal road	NA	NA	NA
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	04	04	MR
	2. Basements	NA	NA	NA
	B. Width of staircase			
	1. Upper floors	1.50 mtr each	1.75 mtr each	MR
	2. Basements	NA	NA	NA
	C. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	04	04	MR
	E. Width of corridor	1.5 mts	1.80 mts	N/A
	F. Door size	1.20 mts	1.23 mts at each class room & hall = 1.35 mts x 4 & 2.80 mts (01 nos.)	MR
3.	Compartmentation			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	NA	NA	NA
	2) Upper floors	12 ACPH	Natural ventilation	MR
5.	Fire Extinguishers			
	1) Total numbers	20 Nos.	Provided	MR
	2) Types	ABC & CO2	ABC, CO2 & W.CO2	MR
	3) ISI marking	Required	Provided	MR
6.	First-Aid Hose Reel			



	1) Number of hose reel per floor	04	Provided	MR
	2) Length of hose reel hose	30 mtr.	Provided	MR
	3) Nozzle diameter	05 mm	Provided	MR
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	N/A	N/A	N/A
	2) Location of main panel	N/A	N/A	N/A
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	N/A	N/A	N/A
	5) Hooter's Location	N/A	N/A	N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	1) Basement	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	N/A	100 mm	N/A
	2) Number of hydrants per floor	N/A	01	N/A
	3) Hose box	N/A	01	N/A
12.	Yard Hydrants			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
13.	Pumping Arrangement			
	1) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	450 LPM x2	Provided	MR
	b) Head of pump	40 mtr	Provided	MR
	c) Power supply	Required	Provided	MR
	d) Auto starting of pump	Required	Provided	MR
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	N/A	N/A	N/A
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	N/A	N/A	N/A
	c) Access to tank	N/A	N/A	MR
	d) Over head tank capacity	10,000 ltrs.	10,000 ltrs.	MR
15.	Exit Signage.	Required	Provided	MR

N/28

16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	N/A	N/A	N/A
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:			N/A

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.

In view of the compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, if agreed, we may issue the FSC to said building. Accordingly, DFA is prepared and put up for kind perusal/approval and sig. please.

Signature of the Inspecting Officer

Name :- Ravinder Singh  
Designation :- DO

Dy. CPO  
Dy. CPO (S2)  
Principal Director  
A.K. MALIK  
3/10/25

F.T. Khan

Dy. CPO (S2)

Dy. CPO (S2)

A.K. MALIK  
3/10/25