



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

c/68



No: F.6/DFS/MS/2025/WZ/ 768

Dated: 06/10/2025

To,

The Principal,
Govt. Boys Sr. Sec. School,
Bhorgarh, Delhi-110040.

Sub:- Renewal of Fire Safety Certificate in respect of Govt. Boys Sr. Sec. School
(ID- 1310022) located at Bhorgarh, Delhi- 110040.

Sir,

This has reference to your E Mail id dated 28/08/2025 on the subject cited above. In this connection, it is to inform you that above said school building was re-visited by the officer concerned of this department on 23/09/2025 to see the compliance of shortcomings communicated vide letter no. F6/DFS/MS/2025/WZ/539 dated 20/06/2025. Sh. Yogesh Kumar (Principal) was present at the time of inspection. During the course of inspection it was observed that shortcomings communicated via above mentioned letter were not rectified yet.

In view of the above, the application for issuance of Fire Safety Certificate is not considered at this stage & rejected. You are advised to rectify the above-mentioned shortcomings under intimation to this department.

Yours Faithfully

(M.K. Chattopadhyay)
Dy. Chief Fire Officer

oe n

Enclosed as above:-

Copy to:-

1. Director of Education, Govt. of NCT Delhi, Old Secretariat, New Delhi.

c/59

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001



No: F.6/DFS/MS/2025/WZ/ 539

Dated: 20/06/2025

To,

The Principal,
Govt. Boys Sr. Sec. School,
Bhorgarh, Delhi-110040.

Sub:- Renewal of Fire Safety Certificate in respect of Govt. Boys Sr. Sec. School (ID- 1310022) located at Bhorgarh, Delhi- 110040.

Sir,

This has reference to your application no. GBSSS/2025/468 dated 27/05/2025 received through outdoor diary no. 2228 dated 29/05/2025 on the subject cited above. In this connection, it is to inform you that the inspection of above said school building has been carried out by officer concerned of this department on 13.06.2025 to see the compliance of the requisite fire safety measures. Sh. Rambir (Estate Manager) was present at the time of inspection.

During the course of inspection it was observed that the building comprised of Ground and three upper floors. Your request for renewal of FSC is rejected as the following shortcomings were observed:-

1. First aid hose reels found provided but not functional and hose reel nozzle found missing at some places.
2. Internal hydrants found removed at upper floors and operating wheel found missing at ground floor.
3. Terrace level pumps found provided but not functional.

You are advised to rectify the above-mentioned shortcoming for taking further action as necessary for renewal of Fire Safety Certificate.

Yours Faithfully

(Atul Garg)
Director

Ph. 011-23414000

Atul Garg

Copy to :-

1. Director of Education, Govt. Of NCT of Delhi, Old Secretariat, New Delhi.