



c/67



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE NEW DELHI- 110 001

No.F.6/DFS/MS/BNQT/NDZ/2026/ 384

Dated: 27/04/2026

To,

Mr. Alok Narula,
Govindam Bhawan (A Unit of AVM Exports Pvt. Ltd.)
Banquet Hall, at 1447- 48/4,
Loni Road, Durgapuri, Delhi – 110032.

Subject:- Govindam Bhawan (A Unit of AVM Exports Pvt. Ltd.) Banquet Hall, at 1447- 48/4, Loni Road, Durgapuri, Delhi – 110032.

Sir,

This has reference to MCD application ID No. 2026032603658 dated 26/03/2026 on the subject cited above. In this connection, the premises have been inspected by the officer concerned of this department on dated 10/04/2026 in presence of Mr. Vineet, Supervisor. The building comprised of ground plus two upper floors but Banquet is running at ground floor and one upper floor only. The following shortcomings was observed during the time of inspection.

1. Fire checked doors found removed.
2. MOEFA provided but not functioning.
3. SPS on terrace is used as kitchen.

In view of above shortcomings, the application for issuance Fire Safety Certificate is **rejected**. The occupancy of the building/premises in absence of requisite fire Safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Dr. S. K TOMAR)
CHIEF FIRE OFFICER
DELHI FIRE SERVICE

o/c @