



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

651



No. F6/DFS/MS/2025/School/ 1052

Dated: 22/08/2025

FIRE SAFETY CERTIFICATE

Certified that the Govt. Boys Senior Secondary School (I.D No-1309022) located at Dhakka, Delhi-110009 comprised of 03 blocks- I & II block comprised of ground + 01 first floor (old building) & 01 new blocks, comprised of ground & 03 upper floors owned/ occupied by Govt. Boys Senior Secondary School was issued Fire Safety Certificated vide this office letter no. F.6/DFS/MS/2021/School/WZ/1035 dated 21/12/2021. The school was inspected by the officer concerned of this department on 07/08/2025 in the presence of Sh. Dharmender (Guard) and observed that all the fire prevention and fire safety arrangements as provided in the school premises found in good working condition. The school building blocks have therefore deemed complied with the requirements under rule 33 of the Delhi Fire Service Rules, 2010 and the building premise is fit for occupancy under Educational "Group B (School)" with effect from 22/08/2025 for a period of three years in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under rule 40, subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010,

Issued on 22/08/2025 at New Delhi by


22.8.2025

Virendra Singh
Chief Fire Officer
Delhi Fire Service

Copy to :-

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 110054.
2. The Principal, Govt. Boys Senior Secondary School (I.D No-1309022) located at Dhakka, Delhi-110009.

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape shall be kept free from any type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipment and method of smooth and speedy safe evacuation of occupants in case of emergency
3. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seem during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities. This Fire Safety Certificate is valid only for permanent building structure as per plan.
5. This fire safety certificate may not be treated in any case of regularizations of unauthorized construction/unauthorized use of land or activities, if any.
6. The owner / occupier shall submit a declaration every year in Form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on the official website of Delhi Fire Service i.e. www.dfs.delhigovt.nic.in.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".

N/22

INSPECTION REPORT

1. Name & address of the building : Govt. Boys Sr. Sec. School, Dhakka, Delhi-110009. (I.D No. 1309022)
2. Type of Occupancy : Educational
3. Type of Case : Renewal
4. Composition of building : 03 blocks- 02 block- Ground + first floors (Old building) & 01- New block - Ground + 03 upper floors
5. Details of previous NOC : F.6/DFS/MS/2021/School/WZ/1035 dated 21/12/2021
6. Fire Safety directives letter No : Nil
7. Date of inspection : 07/08/2025
8. Name of the Inspecting Officers : ADO (RN)
9. Name and designation of officers from the building side : Sh. Dharmender (Guard)
10. Year of Construction : 2011/ 2017
11. Applicant's letter No. : Letter No. GBSSS/DHAKKA/2025/260 dated: 24/07/2025

S.No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Part-IV Requirements	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	06m	09m	MR
	• Gate width	4.5m	4.5m	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	05	05	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	1.50m	I -block- 1.50m each II- block- 1.50m & III- block- 1.70m each (New block)	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	02	02	MR
	e. Width of Corridor	Required	Provided	MR
	f. Door Size	Hall -02 exits of 01m	Provided	MR
3	Compartmentation.			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	NA	NA	NA
	• Upper floors	Required	Natural Ventilation	MR
5	Fire Extinguishers			
	• Total numbers	30nos	30nos	MR
	• Types	ABC/Co2	ABC-25/Co2-05	MR
	• ISI marking	ISI Marked	Provided	MR
6	First-Aid Hose Reels. (New block)			
	• Total numbers on each floor	01	Provided	MR
	• Length of hose reel hose	30m	30m	MR
	• Nozzle diameter	5mm	5mm	MR

Op to

7	Automatic fire detection and alarming system. N/23			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8	MOEFA			
9	Public Address System.			
10	Automatic Sprinkler System.			
	• Basement	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants			
	• Size of riser/down-comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12	Yard Hydrants.			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13	Pumping Arrangements. (for New Block)			
	• Ground Level			
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey Pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/ Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level			
	➤ Discharge of pump	450 LPM	Provided	MR
	➤ Head of the pump	40m	Provided	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for fire fighting. (For New Block)			
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	10,000 LTR	Provided	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply			
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A

N/24

19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection. The management has complied all the shortcomings issued and communicated by this department vide letter of even no. F6/DFS/MS/2025/School/346 dated 07/05/2025.

Keeping in view the satisfactory compliance of the minimum standards on fire prevention and fire safety required as stipulated in NBC Part 4/Director of educational dated 01.03.2011, the FSC issued vide letter of even no. F.6/DFS/MS/2021/School/WZ/1035 dated 21/12/2021, it is **recommended for renewal** under rule 37 of the Delhi Fire Service Rules, 2010.

Signature of the Inspecting Officer
Name :- C.L. Meena
Designation:- ADO/RN

D.B. Mukharjee (DO/NW)

15/08/2025

Dy cfo (102)

13/8

18/01/2025

Principal Director

CFO to Gen.

19/08/25

20/08/2025

ADO(RN)

As approved F.T. letter is Put up for your signature please.

21/08/2025

21/08/2025
ADO(RN)

MS

DCFO/... 258 1112
Dated... 13/8/2025