

C-117

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI – 110001**

No.F.6/DFS/MS/SZ/2026/ 716

Dated: 24/07/2026

To,

The Principal,
Govt. Girls/Boys Sr. Sec School,
Samalkha New Delhi -110097

Subject: Renewal of Fire Safety Certificate in r/o Govt. Girls/Boys Sr. Sec School Samalkha
New Delhi -110097 (School Id-1821280)

Sir,

Please refer to your letter no : GGSSS/SAM/2026/297 dated- 09/06/2026 on the subject mentioned above. In this connection it is to inform you that the premises was inspected by the officer concerned from this department on 07/07/2026 in the presence of Ms. Jayati Kapoor (Principal) for fire safety point of view.

The following shortcoming was observed during the time of inspection:-

1. Hose reel hose found nonfunctional.
2. Terrace pump found nonfunctional.
3. Overhead tank of capacity 10,000 ltr found empty.
4. Exit Signage found removed at same places.

You are requested to comply the above mentioned shortcomings under intimation to this department for further necessary action.

In view of the above shortcomings Fire Safety Certificate cannot be considered at this stage.

Yours faithfully,


23/07/26
(S.K.Dua)
Chief Fire Officer
Delhi Fire Service

Copy to; - Directorate of Education Old Secretariat Delhi – 110054

o/c