

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001**

No.F6/DFS/MS/CH/NDZ/ 2025/SCH/641

Dated:-12/08/2025

To,  
The Principal,  
M/S Govt. Boys Sr. Sec. School,  
Shadi Khampur, New Delhi.

**Sub: Regarding issuance of FSC in r/o M/S Govt. Boys Sr. Sec. School, Shadi Khampur, New Delhi.**

Sir,  
This has reference to letter no mail id <gbsss1516011@gmail.com> dated 06.06.2025, on the subject cited above. In this regard, it is to inform you that the site was visited by officer concerned of this department on 26.07.25 in the presence of Mr. James and **following shortcomings were observed.**

1. Hose reel found non functional.
2. Pump found non functional.

In view of above, fire safety certificate (FSC) cannot be considered at this stage. Therefore, it is requested to rectify the above shortcomings at the earliest for further consideration in the matter.

Yours faithfully,

  
(Virendra Singh)  
Chief Fire Officer  
Delhi Fire Service

Copy to:-

1. The Director (Education), Govt. of NCT, Old Sectt. Delhi - 54.