



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

75
आज़ादी का
अमृत महोत्सव

No. F6/DFS/MS/School/WZ/2025/ 604

Dated: 05/05/2025

FIRE SAFETY CERTIFICATE

Certified that the Govt. Boys Senior Sec. School (New Building), located at Tagore Garden, New Delhi – 110027.(School ID-1515139), comprised of total two blocks ground + 03 upper floors each & 01 MP Hall, owned/Occupied by Govt. Boys Senior Sec. School, was issued FSC vide letter No F6/DFS/MS/School/WZ/2022/714 dated 27/06/2022. The premises was re - inspected by the officer concerned by this department on 24/04/2025, in the presence of Sh. Tej Pal Bhola (Principal) and observed that all the fire prevention & fire safety arrangements provided in the premises found in good working condition. That the building/premises have deemed complied with fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire service Rules 2010 and found that the building / premises is fit for the occupancy class "Educational" Group B with effect from 05/05/2025 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010. Condition mentioned below.

Issued on ...05/05/2025 at New Delhi.

(Atul Garg)
Director

Copy to:-

1. Director of Education, GNCT of NCT of Delhi, Old Secretariat.
2. The Principal, Govt. Boys Senior Sec. School (New Building), located at Tagore Garden, New Delhi – 110027.(School ID-1515139)

Conditions for the validity of FSC:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.

INSPECTION REPORT

1.	Name & address of the building	Govt. Boys Senior Sec. School, located at Tagore Garden, New Delhi – 110027.(School ID-1515139)(New Building)
2.	Type of Occupancy	Educational(total two blocks ground + 03 upper floors each & 01 MP Hall)
3.	Type of Case	Renewal
4.	Details of previous NOC	F6/DFS/MS/School/WZ/2022/714 dated 27/06/2022.
5.	Fire Safety directives letter No	Nil
6.	Date of inspection	24/04/2025 24/04/2025
7.	Name of the Inspecting Officers	Sarabjeet Singh ADO (MN)
8.	Name and designation of officers from the building side	Sh. Sh. Tej Pal Bhola (Principal)
9.	Year of Construction	2022 (As per previous Inspection Report dated 10/06/2022)
10.	Applicant's letter No.	Email dated 17/01/2025.

The said school building comprised of Ground + 03 Upper Floor & 01 MP Hall, was issued FSC vide letter no. F6/DFS/MS/School/WZ/2022/714 dated 27/06/2022.

S. No	Minimum Standards on fire prevention and fire safety U/R 33	As per Rule 35 (6) DFS Rule 2010	Provided at site	Remarks MR/NMR
1	Access to building			
	<ul style="list-style-type: none"> Road width 	06 m	Provided	MR
	<ul style="list-style-type: none"> Gate width 	4.5 m	Provided	MR
	<ul style="list-style-type: none"> Width of internal road 	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> Upper Floors 	02	Provided	MR
	<ul style="list-style-type: none"> Basements 	NA	NA	NA
	b. Width of staircases			
	<ul style="list-style-type: none"> Upper Floors 	1.5m each	Provided	MR
	<ul style="list-style-type: none"> Basements 	NA	NA	NA
	c. Protection of exits			
	<ul style="list-style-type: none"> Fire check door 	NA	NA	NA
	<ul style="list-style-type: none"> Pressurization 	NA	NA	NA
	d. No. of continuous staircases to terrace	NA	One	NA
	e. Width of Corridor	1.5m	Provided	MR
	f. Door Size	2 x 1.20 m class rooms 2 x 2 m M.P. Hall	Provided	MR
3	Compartmentation.			
	<ul style="list-style-type: none"> Fire check door 	NA	NA	NA
	<ul style="list-style-type: none"> Sealing of electrical shafts 	NA	NA	NA
	<ul style="list-style-type: none"> Fire Rating of shaft door 	NA	NA	NA
	<ul style="list-style-type: none"> Water Curtain 	NA	NA	NA
	<ul style="list-style-type: none"> Fire Dampers 	NA	NA	NA
4	Smoke Management System.			
	<ul style="list-style-type: none"> Basements 	NA	NA	NA
	<ul style="list-style-type: none"> Upper floors 	NA	NA	NA
5	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers 	14 nos.	Provided	MR
	<ul style="list-style-type: none"> Types 	CO ₂ , ABC type	Provided	MR
	<ul style="list-style-type: none"> IS marking 	ISI marked	Provided	MR
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> Total numbers on each floor 	02	Provided	MR
	<ul style="list-style-type: none"> Length of hose reel hose 	30 mtrs	Provided	MR
	<ul style="list-style-type: none"> Nozzle diameter 	5 mm	Provided	MR

7	Automatic fire detection and alarming system.			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8	MOEFA	NA	NA	NA
9	Public Address System.	NA	NA	NA
10	Automatic Sprinkler System.			
	• Basement	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants			
	• Size of riser/down-comer	NA	Provided	NA
	• Number of hydrants per floor	NA	Provided	NA
	• Hose Box	NA	Provided	NA
12	Yard Hydrants.			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13	Pumping Arrangements.			
	• Ground Level			
	➤ Discharge of main Pump	NA	NA	NA
	➤ Head of Main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey Pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/ Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	450 LPM	Provided	MR
	➤ Head of the pump	30 m	Provided	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	10,000 ltrs	Provided	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA

17	Standby power supply	NA	NA	NA
18	Refuge Area.			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19	Fire Control Room			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Battery backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the rules, the NOC vide letter no F6/DFS/MS/School/WZ/2022/714 dated 27/06/2022, renewal under the rule 35 of the Delhi Fire Service rules 2010 is recommended.

24/4/2025

25/4/2025

Signature of the Inspecting Officer
Sarabjeet Singh ADO (MN)

23/4

DCFO/.....*29/4/2025*
Dated.....*29/4/2025*

CFD
29/4/2025

Director
34/04/25

Adm/mv

Sir, F.T is put up for your kind perusal & signature
p/s.

Director
2/5/25

25/4/2025