



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/2025/School/ 346

Dated: 07/05/2025

To

The Principal
Govt. Boys Sr. Sec. School
at at Dhakka, Delhi-110009.

Sub: -Regarding issuance of fire safety certificate in r/o Govt. Boys Sr. Sec. School (School ID NO. 1309022) located at Dhakka, Delhi-110009.

Sir,

Please refer to your letter No. GBSSS/DHAKKA/2025/104 dated: 29/04/2025 on the subject cited above. In this connection this is to inform you that the above mentioned site was visited by the officer concerned of this department on 03/05/2025 to check the existing fire safety measures. During inspection it has been observed that the school premise is comprised of 03 blocks, 02 blocks, comprised of ground + first floors & 01 block comprised of ground + 03 upper floors only. At the time of inspection Sh. Sukh Ram (Principal) was also present at site. During the course of inspection the observations/ shortcomings made are as under:-

1. Hose reel hose is provided but not functional.
2. Terrace level fire pump capacity of 450lpm each is provided but not functional.
3. Electrical panel below staircase needs to be removed/shifted in a safer place

Keeping in view of above, grant of Fire Safety Certificate cannot be considered at this stage & rejected. You are requested to rectify the above mentioned shortcomings under intimation to this department; till such time running of school is at your own risk & responsibility.

Yours faithfully

(Atul Garg)
Director

Ph:-011-23414000

Copy to:-

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi-110054.