



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001



No. F.6/DFS/MS/School/2025/SZ/ 663

Dated: 20/08/2025

To

Dr. Seema Dabas (Principal),
Govt. Co-Ed. Sarvodaya Vidyalaya,
Sector 13, Dwarka, New Delhi-110078

Sub: Renewal of Fire Safety Certificate in r/o Govt. Co-Ed. Sarvodaya Vidyalaya located at Sector 13, Dwarka, New Delhi-110078 (School ID: 1821281)

Sir,

This has a reference to your letter No. GCSV-13/DWK/2025-26/233 dated 14/07/2025 received in this department vide outdoor diary No. 3765 dated 15/07/2025. In this connection, it is to inform you that the premise was inspected by the officer concerned of this department on 25/07/2025 from fire safety point of view, in your presence. During course of inspection, the **shortcomings observed are as below.**

1. Portable fire extinguisher provided found unfilled/empty.
2. Terrace level fire pump found non-functional.
3. Overhead water storage tank exclusive for firefighting found empty.

In view of the above, application for renewal of **fire safety certificate cannot be considered at this stage & rejected.** You are requested to rectify the shortcomings under intimation to this department for further action in the matter.

Yours faithfully,


19/8/2025
(Virendra Singh)
Chief Fire Officer
Delhi Fire Service
O/C 8K

Copy to: -

1. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054.