

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE

NEW DELHI- 110001

No. F6/DFS/MS/School/2025/SZ/ 643
To,

Dated: 14/08/2025

The Principal,
Govt. Co-ed Sr. Sec. School,
Khaira, New Delhi- 110043.

Sub: -Regarding renewal of "FSC" from fire safety point of view in r/o Govt. Co-ed Sr. Sec. School at Khaira, Najafgarh, New Delhi- 110043.

Sir,

Please refer to your letter No. Nil dated 15.07.2025, on the subject cited above. In this connection, it is to inform you that officer concerned of this department inspected the school building on dated 25.07.2025 to verify the fire safety arrangements in accordance with the rules. At the time of inspection Sh. Ramesh Kumar (Principal) was present and it was observed that the school building comprised of ground plus three upper floors, and have following shortcomings:-

1. Fire extinguisher found not refilled.
2. Hose Reels 02 nos. at each floor found provided but not functional.
3. Terrace fire pump of 450 LPM found provided by not functional.
4. Exit signage are found removed at some places.

In view of the above, **renewal of 'Fire Safety Certificate' cannot be granted at this stage.** You are requested to rectify the above-mentioned shortcomings under intimation to this department for taking further necessary action in this matter and running school in absence of requisite fire safety arrangements shall be at the risk & liability of the school management.

Yours faithfully


(Virendra Singh)
Chief Fire Officer
Delhi Fire Service

Copy to:-

1. Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054.

: - for necessary action please.