

C-49

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/School/WZ/2025/ 175

Dated: 26/03/2025

To,

The Principal,
Govt. Co-Ed Sarvodaya Vidyalaya,
Sector-04 (Extn.), Rohini,
Delhi-85. (School Id-1413336).

Sub: Issue of FSC in r/o Govt. Co-Ed Sarvodaya Vidyalaya, Sector-04 (Extn.), Rohini, Delhi-110085. (School Id-1413336)

Sir,

Kindly reference to letter received in this department through outdoor diary no. 12588 dated 18.02.2025 on the subject cited above. The premise was inspected by the concern nominated authority of this department on 18.03.2025, in presence of **Mr. Harish Bhardwaj (Principal)** to ascertain the availability and operability of the fire prevention and fire safety measures. Your request for renewal of FSC is rejected under sub rule (3) of Rule 37 of DFS Rules-2010 due to following reason:

1. One electric & one stand by pumps capacity of 2280 lpm & one jockey pump capacity of 220 LPM are not provided.
2. Both terrace Fire pump are provided but not functional.
3. Hose reel nozzle found missing at some places & hose reel not functional.
4. Exit signage at some location found missing.

In this regard as stipulated in sub Rule 37 of DFS Rules, 2010 you may apply with a fresh application for renewal of fire safety certificate under sub-rule (2) on Form "J" with compliance of above shortcomings. The web links for DFS Act-2007/ Rules 2010 & Form "J" are as under:
http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/
http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms

Yours faithfully


(Atul Garg)
DIRECTOR
Ph; 011-23414000

one
only