



C-27

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/2025/School/ 559

Dated: 02/07/2025

To

The Principal,
Govt. (Co-ed) Senior Secondary School
No-1 at Roop Nagar, Delhi-110007.
hos1207039@gmail.com

Sub: Regarding renewal of fire safety certificate in r/o Govt. (Co-ed) Senior Secondary School No-1 (School ID No 1207039) located at Roop Nagar, Delhi-110007.

Sir,

Please refer to your received through online e-mail dated: 20/06/2025 on the subject cited above. In this connection this is to inform you that the above mentioned site was visited by the officer concerned of this department on 26/06/2025 to verify the fire safety measures issued vide NBC Part-IV and observed that the building was comprised of 03 blocks, ground & 03 upper floors each. At the time of inspection Sh. Devender Kumar (Principal) was also present at site. During the course of inspection observations/ shortcomings made are as under:-

- 1 Hose reel hose is provided but not functional and damaged condition.
- 2 Terrace level fire fighting pump capacity of 450 lpm is provided but found not functional and damaged condition.
- 3 Terrace level fire water tank is provided 5,000Ltr of both old blocks against the requirement of 10, 000Ltr at each block.
- 4 Exit signage found removed at strategic locations in the school building.

Keeping in view of above, renewal of Fire Safety Certificate cannot be considered at this stage & rejected. You are requested to rectify the above mentioned shortcomings under intimation to this department; till such time running of buildings is at your own risk & responsibility.

Yours faithfully

(Atul Garg)
Director

Ph:- 011-23414000

Copy to:-

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 110054.