



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001



No. F6/DFS/MS/2025/WZ/School/ 1239

Dated: 08/10/2025

FIRE SAFETY CERTIFICATE

Certified that the Govt. (Co-ed) Senior Secondary School, Sultanpur Majra, Delhi-83. (School ID-1412016) comprised of 02 blocks, A & B blocks, Ground + 03 upper floors has already been issued FSC by this department vide letter No. F.6/DFS/MS/School/WZ/2022/517 dated 12.05.2022. The premises was re-inspected by the officer concerned of this department on 10.09.2025 in the presence of Mr. Raj Kumar (HOS) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises fit for occupancy class "B" Educational Building with effect from 08/10/2025 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subjected to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 08/10/2025 at New Delhi by

M. K. Chattopadhyay
 Dy. Chief Fire Officer
 Delhi Fire Service

Copy to: -

1. The Principal, Govt. (Co-ed) Senior Secondary School, Sultanpur Majra, Delhi-83. (School ID-1412016).
2. The Director of Education, GNCT of Delhi Old Secretariat, Delhi-110054

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on
8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/ http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms

INSPECTION REPORT

1. Name & address of the building : Govt. (Co-ed) Senior Secondary School, Sultanpur Majra, Delhi-83
2. Type of Occupancy : Educational (School ID-1412016)
3. Type of Case : Renewal (02 Blks. A & B Blocks, Ground + 03 upper floors)
4. Details of Previous NOC : F.6/DFS/MS/School/WZ/2022/517 dated 12.05.2022.
5. Fire Safety directives letter No : NBC Part-IV
6. Date of inspection : 10.09.2025
7. Name of Inspecting Officer : A.K.Sharma ADO(Rohini)
8. Name and designation of officers : Mr. Raj Kumar (HOS)
9. Year of Construction : 2021
10. Applicant's letter No. : Online e-mail dated 01.09.2025.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	6.0m	Accessible	MR
	• Gate width	4.5m	Accessible	MR
	• Width of internal road	-NA-	-NA-	-NA-
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	A-Blk-03nos. B-Blk-02nos.	A-Blk-03nos. B-Blk-02nos.	MR MR
	• Basements	-NA-	-NA-	-NA-
	b. Width of staircases			
	• Upper Floor	A-Blk-1.5m B-Blk-1.5m	A-Blk-1.5m B-Blk-1.5m	MR MR
	• Basements	-NA-	-NA-	-NA-
	c. Protection of exits			
	Fire check door	-NA-	-NA-	-NA-
	• Pressurization	-NA-	-NA-	-NA-
	d. No. of continuous staircases to terrace	A-Blk-03nos. B-Blk-02nos.	A-Blk-03nos. B-Blk-02nos.	MR MR
	e. Width of Corridor	A-Blk-1.5m B-Blk-1.5m	A-Blk-1.70m B-Blk-1.70m	MR MR
	f. Door Size	-NA-	-NA-	-NA-
3.	Compartmentation			
	• Fire check door	-NA-	-NA-	-NA-
	• Sealing of electrical shafts	-NA-	-NA-	-NA-
	• Fire Rating of shaft door	-NA-	-NA-	-NA-
	• Water Curtain	-NA-	-NA-	-NA-
	• Fire Dampers	-NA-	-NA-	-NA-
4.	Smoke Management System			
	• Basements	-NA-	-NA-	-NA-
	• Upper floors	12 a/c per hour	Natural ventilated	MR
5.	Fire Extinguishers			
	• Total numbers	A-Blk-30 B-Blk-22	A-Blk-provided B-Blk-provided	MR MR
	• Types	ABC/CO2	ABC/CO2	MR
	• IS marking	ISI marked	Yes	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor	A-Blk-03nos. B-Blk-02nos.	Provided Provided	NMR NMR
	• Length of hose reel hose	30mm	Provided	MR
	• Nozzle diameter	5m	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	-NA-	-NA-	-NA-

N/26

20.	• Flow Switch Panel	-NA-	-NA-	-NA-
	• PA System Panel	-NA-	-NA-	-NA-
	• Battery backup	-NA-	-NA-	-NA-
	• Building Floor Plans	-NA-	-NA-	-NA-
20.	Special Fire Protection System for Protection of special Risks, if any:	-NA-	-NA-	-NA-

Accordingly, the fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required as stipulated in NBC Part-4, and removal of shortcomings issued vide letter no. 582 dated 10.07.2025, the FSC issued vide letter no. F.6/DFS/MS/School/WZ/2022/517 dated 12.05.2022, renewal of FSC under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.

Signature of the Inspecting Officer
Name Ajay Kumar Sharma
Designation ADO (Rohini)

DO (NW) N/A

Dy. CEO (WZ)

Correct & put up

10/9/2025

~~ADO (Rohini)~~

ADO (Rohini)

There is no FCO in exits, therefore, Door width is NA as approved in previous Px. put up again for kind perusal and approval please.

27/9/25

~~Dy. CEO (WZ)~~

28/9/2025

CFo - not available

principal director Dy. CEO to Secm.

Dy. CEO (WZ) 02/10/25

ADO (Rohini)