

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI - 110001

No.F6/DFS/MS/School/NDZ/2025/ 721

Dated: 30/05/2025

FIRE SAFETY CERTIFICATE

Certified that the **Govt. Co-Ed, Senior Secondary School (ID No. 1208091), Sushila Mohan Marg, Naya Bazar, Delhi - 110006**, comprised of **(01 New Block) ground + 03 upper floors only** owned /occupied by **Govt. Co-Ed Senior Secondary School** was granted FSC by this department vide letter No. F6/DFS/MS/2022/School/WZ/260 dated 11.03.2022. The premises was re-inspected by the officer concerned of this department on 15.05.2025 in the presence of Mr. Jai Prakash (Teacher) and found that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of Delhi Fire Service Rules, 2010. Accordingly, the building/premises is fit for occupancy class **(Group- B) "Educational Building"**, **01 New Block (ground + 03 upper floors)** with effect from ...30/05/2025 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010 printed below.

Issued on...30/05/2025...at New Delhi by.


(Atul Garg)
 Director

Delhi Fire Service
 Tel: 011-23414000

Copy to:-

1. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, Delhi.
2. The Principal, Govt. Co-Ed, Senior Secondary School (ID No. 1208091), Sushila Mohan Marg, Naya Bazar, Delhi - 110006.

Conditions for the validity of Fire Safety Certificate:-

1. All the means of escape/entry/exit/shall kept free from any obstruction.
2. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
6. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT					
1	Name & address of the building		Govt. Co-Ed, Senior Secondary School, Sushila Mohan Marg, Naya Bazar, Delhi - 110006.		
2	Building is comprised of		(01 New Block) Ground + 03 upper floors		
3	Type of occupancy		"Education Building"		
4	Type of case		Renewal		
5	Details of previous FSC		F6/DFS/MS/2022/School/WZ/260 dated 11.03.2022		
6	Fire safety direction letter no.		Nil		
7	Date of inspection		15.05.2025		
8	Name of the inspecting officers		ADO (SPM)		
9	Name of the designation of officer from the building side		Mr. Jai Prakash (Teacher)		
10	Year of construction		2019-20		
11	Applicant's letter no.		Email dated 01.04.2025		
S.No	Minimum Standards on fire Prevention and fire safety requirements U/R 33		NBC Requirements	Provided at Site	Remarks MR/ NMR
1	Access To Building:				
	Road width	06 m	06 m		MR
	Gate width	06 m	06 m		MR
	Width of internal road	NA	NA		NA
2	Number, Width, Type and Arrangement of Exits:				
	A	Number of staircases			
	a	Upper floor	02 nos.	02 nos.	MR
	b	Basement	NA	NA	NA
	B	Width of staircases			
	a	Upper floor	1.50 mtrs.	1.70 mtrs. each	MR
	b	Basement	NA	NA	NA
	C	Protection of exits			
	a	Fire check door	NA	NA	NA
	b	Pressurization	NA	NA	NA
	D	No. of continuous staircases to terrace	02 nos.	02 nos.	MR
	E	Width of corridor	1.5 m	1.5 m	MR
	F	Door size	1.20 mtr.	1.20 mtr.	MR
3	Compartmentation:				
	A	Fire check door	NA	NA	NA
	B	Sealing of electrical shafts	NA	NA	NA
	C	Fire rating of shaft door	NA	NA	NA
	D	Water curtain	NA	NA	NA
	E	Fire dampers	NA	NA	NA
4	Smoke Management System:				
	A	Basements	NA	NA	NA
	B	Upper Floor	12 ACPH	Natural / Ventilation	MR

5. Fire Extinguisher:				
A	Total numbers	16 nos.	18 nos.	MR
B	Types	CO ₂ & ABC	CO ₂ & ABC	MR
C	ISI marking	ISI marked	ISI marked	MR
6 First-Aid-Hose Reels:				
A	Total numbers of each floor	02 nos.	Provided	MR
B	Length of hose reel hose	30 m	30 m	MR
C	Nozzle diameter	05 mm	05 mm	MR
7 Automatic Fire Detection And Alarming System:				
A	Type of detectors	NA	NA	NA
B	Location of main panel	NA	NA	NA
C	Location of repeater panel	NA	NA	NA
D	Alternate source of power	NA	NA	NA
E	Hooters	NA	NA	NA
8	MOEFA:	NA	NA	NA
9	Public Address System:	NA	NA	NA
10 Automatic Sprinkler System:				
A	Basement	NA	NA	NA
B	Upper floor	NA	NA	NA
C	Sprinkler above false ceiling	NA	NA	NA
11 Internal Hydrants:				
A	size of riser/down-comer	NA	NA	NA
B	Number of hydrants per floor	NA	NA	NA
C	Hose box	NA	NA	NA
12 Yard Hydrants:				
A	Total number of hydrants	NA	NA	NA
B	Hose box	NA	NA	NA
13 Pumping Arrangements:				
A	Ground level			
a)	Discharge of main pump	NA	NA	NA
b)	Head of main pump	NA	NA	NA
c)	Number of main pumps	NA	NA	NA
d)	Jockey pump out put	NA	NA	NA
e)	Jockey pump head	NA	NA	NA
f)	Standby pump out put	NA	NA	NA
g)	Standby pump head	NA	NA	NA
h)	Auto starting /manual stopping	NA	NA	NA
i)	Pump house access	NA	NA	NA
B	Terrace level			
a)	Discharge of pump	450 LPM	450 LPM x 02	MR
b)	Head of the pump	40 m	40 m	MR
c)	Power supply	Required	Provided	MR
d)	Auto starting of pump	Required	Provided	MR

14	Captive Water Storage For Fire Fighting:			
A	Underground tank capacity	NA	NA	NA
B	Draw-off connection	NA	NA	NA
C	Fire service inlet	NA	NA	NA
D	Access to tank	NA	NA	NA
E	Overhead tank capacity	10,000 ltrs.	10,000 ltrs.	MR
15	Exit Signage:		Required	Provided
				MR
16	Provision of Lifts:			
A	Pressurization of lift shaft	NA	NA	NA
B	Pressurization of lift lobby	NA	NA	NA
C	Communication in lift car	NA	NA	NA
D	Firemen's grounding switch	NA	NA	NA
E	Lift signage	NA	NA	NA
17	Standby Power Supply:		NA	NA
18	Refuge Area:			
A	Total area	NA	NA	NA
B	Location	NA	NA	NA
19	Fire Control Room :			
A	Detector system panel	NA	NA	NA
B	Flow switch panel	NA	NA	NA
C	Pa system panel	NA	NA	NA
D	Battery backup	NA	NA	NA
E	Building floor plans	NA	NA	NA
20	Special Fire Protection Systems For Protection of Special Risks, If Any:		NA	NA

The fire protection systems provided in the building were tested, checked at random and found functional at the time of inspections.

In view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the Rules, the FSC issued vide letter no. F6/DFS/MS/2022/School/WZ/260 dated 11.03.2022 is recommended to be renewed under Rule 35 of the Delhi Fire Service Rules 2010.

Accordingly, DFA is put up for approval & signature please.

[Signature]
20/05/2025

Signature of the Inspecting Officer
Name Sumit Kumar
Designation ADO (SPM)

DO (CD)

[Signature]
21/5/25

[Signature]
Dy. C.F.O. (WZ)

[Signature]
21/05/25

C.F.O.

[Signature]
1/22/5/2025
Director (WZ)

[Signature]
Director (DFS)

F.T. letter is put up for signature, please.

[Signature]
21/05/2025