



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F.6/DFS/MS/School/2025/SZ/ 74

Dated: 28 / 01 / 2025

To

The Principal,  
Govt. Co-Ed. Sarvodaya Vidyalaya,  
Sector-17, Dwarka New Delhi.

Sub: **Renewal of Fire Safety Certificate in r/o Govt. Co-Ed. Sarvodaya Vidyalaya located at Sector-17, Dwarka New Delhi (School ID: 1821279).**  
Sir,

This has a reference to your application (Form 'J') received through outdoor diary No. 10295 dated 13/12/2024, on the subject above. In this connection it is to inform you that the premises was inspected by the officer concerned from this department on 13/01/2025 in the presence of Mr. Bhajan Singh Negi (Estate Manager) from fire safety point of view. During the course of inspection following shortcomings are observed: -

1. Hose box found empty.
2. Hose reel found non-functional and nozzle missing.
3. Terrace pump found non-functional.
4. Exit signage's found removed at some locations.
5. Lift signage's found removed

In view of the above shortcomings, renewal of Fire Safety Certificate is rejected and you are advised to rectify the shortcomings under intimation to this department for further consideration in the matter. The occupancy of the premise/building in the absence of requisite fire safety arrangement shall be at the risk and responsibility of school management.

Yours faithfully,

(ATUL GARG)  
DIRECTOR

T. No. 011-23414000

Copy to: -

1. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054