

c/43

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE**

NEW DELHI

No. F6/DFS/MS/School/WZ/2025/ 830

Dated: 25/06/2025

**FIRE SAFETY CERTIFICATE**

Certified that the Govt. Co-ed. Sec. School, located at, Raghubir, Nagar J.J. Colony, New Delhi-110027.(School ID-1515019), is running in total four blocks (A, B, C & D blocks), 03 blocks (A, B & C blocks), comprised of ground + 01 upper floor only was issued FSC vide letter no. F6/DFS/MS/School/WZ/2021/1037 dated 21/12/2021 & one block (D block) is comprised of ground + 03 upper floors, already issued FSC vide letter No. F6/DFS/MS/School/WZ/2022/27 dated 12/01/2022, owned/occupied by Govt. Co-ed. Sec. School. The premises was re-inspected by the officer concerned by this department on 11/06/2025 in the presence of Ms. Sunita Meena (Principal) and observed that all the fire prevention & fire safety arrangements provided in the premises found in good working condition. That the building/premises have deemed complied with fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire service Rules 2010 and found that the building / premises is fit for the occupancy class "Educational" Group B (for 03 blocks Ground + 1 upper floor & ground + 03 upper floors block (new building) only ) with effect from 25/06/25 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010 Condition mentioned below.

Issued on 25/06/2025 at New Delhi.

(Atul Garg)  
Director  
Delhi Fire Service

Copy to:

1. Director of Education, GNCT of NCT of Delhi, Old Secretariat.
2. The Principal, Govt. Co-ed. Sec. School, located at, Raghubir, Nagar J.J. Colony, New Delhi-110027. (School ID-1515019). Email ID-1515019z15gcd@gmail.com.

**Conditions for the validity of FSC:-**

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.



# INSPECTION REPORT

1.	Name & address of the building	Govt. Co-ed. Sec. School, located at, Raghubir, Nagar J.J. Colony, New Delhi-110027.(School ID-1515019)
2.	Type of Occupancy	Educational(03 Blocks of Ground Floor + 01 Upper Floor) & (New Building for Ground + 03 Upper Floors)
3.	Type of Case	Renewal
4.	Details of previous NOC	F6/DFS/MS/School/WZ/2021/1037 dated 21/12/2021(ground+ 01 block) & F6/DFS/MS/School/WZ/2022/27 dated 12/01/2022(for ground + 03 block)
5.	Fire Safety directives letter No	DOE 3298-3398 dated 01/03/2011
6.	Date of inspection	11/06/2025
7.	Name of the Inspecting Officers	Sarabjeet Singh ADO (MN)
8.	Name and designation of officers from the building side	Ms. Sunita Meena (H. O. S.)
9.	Year of Construction	2011 (As per previous Inspection Report dated 07/12/2021)
10.	Applicant's letter No.	Email dated 06/05/2025 & 22/04/2025.

The said school is running in total four blocks (A, B, C & D blocks), 03 blocks (A, B & C blocks), comprised of ground + 01 upper floor only was issued FSC vide letter no. F6/DFS/MS/School/WZ/2021/1037 dated 21/12/2021 & one block (D block) is comprised of ground and three upper floors already issued FSC vide letter No. F6/DFS/MS/School/WZ/2022/27 dated 12/01/2022.

S. No	Minimum Standards on fire prevention and fire safety U/R 33	As per Rule 35 (6) DFS Rule 2010	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	Accessible	6m Provided	MR
	• Gate width	Accessible	Provided	MR
	• Width of internal road	NA	NA	NA
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	• Upper Floors	9	A Block = 2, B Block = 2, C Block = 3, D Block=2	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	1.5 m	A Block = 143 cm, 145 cms B Block= 138, 146cm Iran Stair C Block=153cm, 154cm, 155 cm D Block=1.5 m x 2	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	1.5 m	A Block = 154 cm, B Block 175 cm C Block = 175 cm D Block=1.5 m	MR
	f. Door Size	1m	2X1m Provided	MR
3	<b>Compartmentation.</b>			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA

4	<b>Smoke Management System.</b>			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA
5	<b>Fire Extinguishers</b>			
	• Total numbers	13 nos.	25 Provided	MR
	• Types	CO <sub>2</sub> , ABC type	Provided	MR
	• IS marking	ISI marked	Provided	MR
6	<b>First-Aid Hose Reels.</b>			
	• Total numbers on each floor	02 Required (for G + 03)	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7	<b>Automatic fire detection and alarming system.</b>			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8	<b>MOEFA</b>	NA	NA	NA
9	<b>Public Address System.</b>	NA	NA	NA
10	<b>Automatic Sprinkler System.</b>			
	• Basement	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11	<b>Internal Hydrants</b>			
	• Size of riser/down-comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12	<b>Yard Hydrants.</b>			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13	<b>Pumping Arrangements.</b>			
	• Ground Level			
	➤ Discharge of main Pump	NA	NA	NA
	➤ Head of Main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey Pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/ Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level	<b>For Ground + 03 Floors</b>		
	➤ Discharge of pump	450 LPM	Provided	MR
	➤ Head of the pump	NA	NA	NA
	➤ Power Supply	NA	NA	NA
	➤ Auto Starting of pump	NA	NA	NA



14 Captive Water Storage for fire fighting.		For Ground + 03 Floors		
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	10,000 ltr	Provided	MR
15	Exit Signage.	Required for g + 03 blocks	Provided	MR
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17	Standby power supply	NA	NA	NA
18	Refuge Area.			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19	Fire Control Room			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Battery backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the rules, the NOC vide letter no F6/DFS/MS/School/WZ/2021/1037 dated 21/12/2021(ground+ 01 block) & F6/DFS/MS/School/WZ/2022/27 dated 12/01/2022(for ground + 03 block), renewal under the rule 35 of the Delhi Fire Service rules 2010 is recommended.

ADP/MN  
108/2025

24/06/2025

Signature of the Inspecting Officer  
Sarabjeet Singh ADO (MN)

16/6/25

CFO/11/11/2025

Director

ADP/MN