



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE**  
**NEW DELHI- 110001**

No. F.6/DFS/MS/School/2025/SZ/556

Dated: 01.../07.../2025

To

The Principal,  
Govt. Co-ed Sr. Sec. School  
B Block, PWD Barracks, Kalkaji,  
New Delhi -110019

Sub: Regarding issuance of FSC in r/o Govt. Co-ed Sr. Sec. School (Hearing Impaired) B Block, PWD Barracks, Kalkaji, New Delhi -110019 (School ID 1925453)

Sir,

This has reference to your letter no. HOS/GSSSS (Co-ed) Kalkaji/2023/D/309 dated 21/05/2025 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 23.06.2025 in the presence of Dr. Ranjan Kumar (HOS) to verify the fire safety measures installed in the building. Accordingly fire safety arrangement were tested / checked and found following observation.

1. First aid hose reel not provided.
2. Terrace level Fire Pump capacity of 450 LPM not provided.
3. Overhead tank capacity 10,000 ltrs not provided.

The same observations has already been issued and communicated earlier by this department vide letter of even no 19 dated 17/01/2024.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully,

(ATUL GARG)  
DIRECTOR

DELHI FIRE SERVICE

o/m