

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001



No. F6/DFS/MS/2025/School/WZ/ 634

Dated: 09/05/2025

FIRE SAFETY CERTIFICATE

Certified that the **Govt. Co-Ed Sarvodaya Vidyalaya, Sector-04 (Extn.), Rohini, Delhi-110085**, comprised of **Basement + Ground + Three upper floors** has already been issued FSC by this department vide letter No. **F.6/DFS/MS/2022/School/WZ/330 dated 29.03.2022**. The premises was re-inspected by the officer concerned of this department on **16.04.2025** in the presence of **Mr. Harish Bhardwaj (Principal)** and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises fit for occupancy **Class "Group B Educational"** with effect from 09/05/2025 for a period of **three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subjected to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 09/05/2025 at New Delhi by


(Atul Garg)
DIRECTOR
Ph; 011-23414000

Copy to: -

1. The Director, Education, Government of N.C.T of Delhi. Old Sect. Delhi - 54.
2. The Principal, Govt. Co-Ed Sarvodaya Vidyalaya, Sector-04 (Extn.), Rohini, Delhi-110085.

Conditions for the validity of fire safety certificate:

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection.
3. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of firefighting system.
5. The owner/ occupier shall submit a declaration **every year** in **Form 'K'** [sub rule (2) of Rule 38] provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on http://delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms
6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction (Clause 2.9.2 of UBBL-2016) or Alteration (Clause 1.4.3 of UBBL-2016), if any.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in **Form 'J'** [sub rule (1) of Rule 37] along with a copy of this Certificate, **six months** prior to its expiry."
8. **One electric & one standby pumps capacity of 2280lpm & one jockey pump capacity of 220lpm shall be provided with in six months, failing which it will be considered null & void.**

INSPECTION REPORT

1. Name & address of the building	Govt. Co-Ed Sarvodaya Vidyalaya, Sector-04 (Extn.), Rohini, Delhi-110085. (School Id-1413336)			
2. Type of Occupancy	Educational			
3. Type of Case	Renewal (Basement + Ground + 03 upper floors)			
4. Details of Previous NOC	F.6/DFS/MS/2022/School/WZ/330 dated 29.03.2022.			
5. Fire Safety directives letter No	NBC Part-IV.			
6. Date of inspection	16.04.2025			
7. Name of Inspecting Officer	Sh. Ajay Kumar Sharma (ADO Rohini)			
8. Name and designation of officers From the building side	Mr. Harish Bhardwaj (Principal)			
9. Year of Construction	2017			
10. Applicant's letter No.	Online e-mail dated 03.04.2025.			
S. No	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			MR
	• Road width	Accessible	Accessible	MR
	• Gate width	Accessible	6.0m	MR
	• Width of internal road	-NA-	-NA-	-NA-
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			MR
	• Upper Floors	03nos.	03nos.	MR
	• Basements	02 SC & 1ramp	02 SC & 1ramp	MR
	b. Width of staircases			MR
	• Upper Floor	2.0m	2.0m	MR
	• Basements	2.0m	2.0m & 3m ramp	MR
	c. Protection of exits			-NA-
	• Fire check door	-NA-	-NA-	-NA-
	• Pressurization	-NA-	-NA-	-NA-
	d. No. of continuous staircases to terrace	-NA-	-NA-	-NA-
	e. Width of Corridor	02nos.	Provided	MR
	f. Door Size	Required	Provided	MR
3.	Compartmentation	-NA-	-NA-	-NA-
	• Fire check door	-NA-	-NA-	-NA-
	• Sealing of electrical shafts	-NA-	-NA-	-NA-
	• Fire Rating of shaft door	-NA-	-NA-	-NA-
	• Water Curtain	-NA-	-NA-	-NA-
	• Fire Dampers	-NA-	-NA-	-NA-
4.	Smoke Management System			MR
	a) Basements	30 a/c per hour	Exhaust fan	MR
	b) Upper floors	12 a/c per hour	Natural ventilated	MR
5.	Fire Extinguishers			MR
	• Total numbers	50nos.	Provided	MR
	• Types	ABC/CO2	ABC/CO2	MR
	• ISI marking	ISI marked	Yes	MR
6.	First-Aid Hose Reels			MR
	• Total numbers on each floor	03nos.	Provided	MR
	• Length of hose reel hose	30mm	Provided	MR
	• Nozzle diameter	5m	Provided	MR
7.	Automatic fire detection and alarming system			

	a) Type of detectors	-NA-	-NA-	-NA-
	b) Location of Main Panel	-NA-	-NA-	-NA-
	c) Location of Repeater Panel	-NA-	-NA-	-NA-
	d) Alternate source of power	-NA-	-NA-	-NA-
	e) Hooters' Location	-NA-	-NA-	-NA-
8.	MOEFA	-NA-	-NA-	-NA-
9.	Public Address System	-NA-	-NA-	-NA-
10.	Automatic Sprinkler System			
	• Basement	Required	Provided	MR
	• Ground & Upper Floors	-NA-	-NA-	-NA-
	• Sprinkler above false ceiling	-NA-	-NA-	-NA-
11.	Internal Hydrants			
	• Size of riser/down-comer	-NA-	100mm	-NA-
	• Number of hydrants per floor	-NA-	03nos.	-NA-
	• Hose Box	-NA-	03nos.	-NA-
12.	Yard Hydrants			
	• Total number of hydrants	-NA-	06nos.	-NA-
	• Hose Box	-NA-	02nos.	-NA-
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main Pump	2850lpm	shall be provided with in six months	---
	➤ Head of Main pump	40m	shall be provided with in six months	---
	➤ Number of main pumps	Required	shall be provided with in six months	---
	➤ Jockey Pump out put	220lpm	shall be provided with in six months	---
	➤ Jockey pump head	40m	shall be provided with in six months	---
	➤ Standby Pump out put	2850lpm	shall be provided with in six months	---
	➤ Standby Pump Head	40m	shall be provided with in six months	---
	➤ Auto Starting/Manual Stopping	Required	shall be provided with in six months	---
	➤ Pump House Access	Required	Provided	---
	Terrace level			
	➤ Discharge of pump	450lpm	2 x 900lpm provided	MR
	➤ Head of the pump	40m	Provided	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14.	Captive Water Storage for fire fighting			
	• Underground tank capacity	50000ltr	1,00000ltr	MR
	➤ Draw-off connection	-NA-	-NA-	-NA-
	➤ Fire service inlet	-NA-	-NA-	-NA-
	➤ Access to tank	-NA-	-NA-	-NA-
	• Overhead Tank capacity	10,000ltr	20,000ltr	MR
		Required	Provided	MR
15.	Exit Signage.			
16.	Provision of Lifts.			
	• Pressurization of Lift Shaft	-NA-	-NA-	-NA-
	• Pressurization of Lift lobby	-NA-	-NA-	-NA-
	• Communication In lift Car	-NA-	-NA-	-NA-

N/28

-NA-	• Fireman's Grounding Switch	-NA-	-NA-	-NA-
-NA-	• Lift Signage	-NA-	-NA-	-NA-
17.	Standby power supply	-NA-	-NA-	-NA-
18.	Refuge Area.			
	➤ Total Area	-NA-	-NA-	-NA-
	➤ Location	-NA-	-NA-	-NA-
19.	Fire Control Room			
	• Detector System Panel	-NA-	-NA-	-NA-
	• Flow Switch Panel	-NA-	-NA-	-NA-
	• PA System Panel	-NA-	-NA-	-NA-
	• Battery backup	-NA-	-NA-	-NA-
	• Building Floor Plans	-NA-	-NA-	-NA-
20.	Special Fire Protection System for Protection of special Risks, if any:	-NA-	-NA-	-NA-

Accordingly, the fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.

Keeping in view the satisfactory compliance of the minimum standards on fire prevention and fire safety required as stipulated in NBC Part-4, and removal of shortcomings issued vide letter no. 175 dated 26.03.2025, the FSC issued vide letter no. F.6/DFS/MS/2022/School/WZ/330 dated 29.03.2022, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.

Signature of the Inspecting Officer
Name Ajay Kumar Sharma
Designation ADO(Rohini)

D.B Mukherjee -
DO (NW)

DCFO (WZ)

DCFO 16-11-22
Date 5/5/2025

5/5/2025

CFD/
6/5/2025
Director
5/5/2025

FT letter is put up
for kind perusal and
signature please.