

C/51

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI- 110001

No. F6/DFS/MS/School/2025/SZ/ 443

Dated: 23/05/2025

To,

The Principal,
Govt. Co-ed Sr. Sec. School No. 3,
Palam Enclave, New Delhi- 110045.

Sub: - Regarding renewal of "Fire Safety Certificate" from fire safety point of view in r/o Govt. Co-ed Sr. Sec. School No. 3 (School Id - 1821024) at Palam Enclave, New Delhi- 110045.

Sir,

Please refer to your letter No. Form 'J' dated 21.04.2025, on the subject cited above. In this connection this is to inform you that officer concerned of this department inspected the school building on dated 19.05.2025 to verify the fire safety arrangements in accordance with the rules. At the time of inspection Ms. Gargi Dhar (Principal) was present and it was observed that the school building having 04 blocks namely A & B Block (G+3 upper floors each), Block C & D (G+1 upper floor each) and block E & F (Ground floor each), and have following shortcomings: -

1. First Aid Hose Reels found provided but found not functional in A & B Block.
3. Terrace fire pump of 450 LPM found provided but found not functional in A & B Block.
5. Exit signages are found removed at some places.

In view of the above, renewal of 'Fire Safety Certificate' cannot be granted at this stage. You are requested to rectify the above-mentioned shortcomings under intimation to this department for taking further necessary action in this matter and running school in absence of requisite fire safety arrangements shall be at the risk & liability of the school management.

Yours faithfully


(Atul Garg)
Director
Delhi Fire Service

Copy to: -

1. Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054.