

C-43



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**



No. F6/DFS/MS/2025/School/ 153

Dated: 13/03/2025

To

The Principal,  
Govt. Girls/Boys Sr. Sec. School  
Azadpur Village, Delhi-110033

**Sub: -** Regarding renewal of fire safety certificate in r/o Govt. Girls/Boys Sr. Sec. School (School ID. No-1309129-30) located at Azadpur Village, Delhi-110033.

Sir,

Please refer to your letter No- GGSSS/APS/2025/89 dated: 21.02.2025 on the subject cited above. In this connection this is to inform you that the above mention site was visited by the officer concerned of this department on 07.03.2025 in the presence of Sh. A.S. Bhandari (Estate Manager) was also present at site to check the existing fire safety & means of escape measures. During inspection it has been observed that the education building is comprised of 04 blocks interconnected, Ground & 03 upper floors each. The observations/ shortcomings made are as under:-

1. First aid hose reel hose is provided but not functional and some nozzle found missing.
2. Terrace level fire pump capacity of 450lpm is provided but not functional.
3. Terrace level fire fighting water tank capacity of 10,000ltr is provided but empty.
4. Electrical panel below in staircase needs to be removed/shifted in a safer place.

Keeping in view of above, renewal of Fire Safety Certificate cannot be considered at this stage & rejected. You are requested to rectify the abovementioned shortcomings under intimation to this department; till such time running of building is at your own risk & responsibility.

Yours faithfully

(Atul Garg)  
Director

Ph:-011-23414000

Copy to:-

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 110054.