



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**



c/38

No: F.6/DFS/MS/2024/WZ/ 453

Dated: 26/05/2025

To,

The Principal,  
Govt. Girls Sr. Sec. School,  
AP Block, Shalimar Bagh,  
Delhi-110088.

**Sub:- Renewal of Fire Safety Certificate in respect of Govt. Girls Sr. Sec. School located at AP- Block, Shalimar Bagh, Delhi- 110088.**

Sir,

This has reference to your email id dated 02/05/2025 on the subject cited above. In this connection, it is to inform you that the inspection of above said school building has been carried out by officer concerned of this department on 19.05.2025 to see the compliance of the requisite fire safety measures. Smt. Renu Yadav (H.O.S.) was present at the time of inspection.

During the course of inspection it was observed that the building comprised of Ground and two upper floors. Your request for renewal of FSC is rejected as the following shortcomings were observed:-

1. First aid hose reels found provided but not functional and hose reel nozzle found missing at some places.
2. Internal hydrants found provided but not functional, operating wheel found missing at some places and hose boxes found without hose pipes.
3. Terrace level pump found provided but not functional.

You are advised to rectify the above-mentioned shortcoming for taking further action as necessary for renewal of Fire Safety Certificate.

Yours Faithfully

(Atul Garg)  
Director

Ph. 011-23414000

all R  
21/5/25

Copy to :-

1. Director of Education, Govt. Of NCT of Delhi, Old Secretariat, New Delhi.