

C 63

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F.6/DFS/MS/School/WZ/2025/250

Dated: 18/03/2025

FIRE SAFETY CERTIFICATE

Certified that the Govt. Girls Sr. Sec. School, Mubarakpur Dabas, Delhi-110081, (School Id-1412133) comprised of Ground + 03 upper floors has already been issued FSC by this department vide letter No. F.6/DFS/MS/School/WZ/2022/290 dated 16.03.2022. The premises was re-inspected by the officer concerned of this department on 06.03.2025 in the presence of Mrs. Sunita Dabas (In-charge) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises fit for occupancy class **Group B Educational** with effect from 18/03/2025 for a period of **three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subjected to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010

Issued on 18/03/2025 at New Delhi by


(Atul Garg)
DIRECTOR
Ph; 011-23414000

Copy to:

1. The Principal, Govt. Girls Sr. Sec. School, Mubarakpur Dabas, Delhi-110081. (School Id-1412133)
 2. The Director of Education, GNCT of Delhi Old Secretariat, Delhi-110054
- Conditions for validity of Fire Safety Certificate;**

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form "K" is available on

http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/
http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms

INSPECTION REPORT

1. Name & address of the building : Govt. Girls Sr. Sec. School, Mubarakpur Dabas, Delhi-110081.
(School ID-1412133)
2. Type of Occupancy : Educational
3. Type of Case : Renewal (Ground + 03 upper floors)
4. Details of Previous NOC : F.6/DFS/MS/School/WZ/2022/290 dated 16.03.2022
5. Fire Safety directives letter No : NBC Part-IV
6. Date of inspection : 06.03.2025
7. Name of Inspecting Officer : A.K.Sharma ADO(Rohini)
8. Name and designation of officers
From the building side : Mrs. Sunita Dabas (In-charge)
9. Year of Construction : 2021
10. Applicant's letter No. : Online e-mail dated 24.02.2025.


S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	6.0m	9.0m	MR
	• Gate width	4.5m	5.8m	MR
	• Width of internal road	-NA-	-NA-	-NA
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	04nos.	04 + 01 ramp	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floor	1.5m each	1.60m each	MR
	• Basements	-NA-	-NA-	-NA
	c. Protection of exits			
	Fire check door	-NA-	-NA-	-NA
	• Pressurization	-NA-	-NA-	-NA
	d. No. of continuous staircases to terrace	04nos	04nos.	MR
	e. Width of Corridor	1.5m	1.80m	MR
	f. Door Size	-NA-	-NA-	-NA
3.	Compartmentation			
	• Fire check door	-NA-	-NA-	-NA
	• Sealing of electrical shafts	-NA-	-NA-	-NA
	• Fire Rating of shaft door	-NA-	-NA-	-NA
	• Water Curtain	-NA-	-NA-	-NA
	• Fire Dampers	-NA-	-NA-	-NA
4.	Smoke Management System			
	• Basements	-NA-	-NA-	-NA
	• Upper floors	12 a/c per hour	Natural ventilated	MR
5.	Fire Extinguishers			
	• Total numbers	40nos.	80nos.	MR
	• Types	ABC/CO2	ABC/CO2	MR
	• IS marking	ISI marked	Yes	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor	05nos.	Provided	MR
	• Length of hose reel hose	30mm	Provided	MR
	• Nozzle diameter	5m	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	-NA-	-NA-	-NA
	• Location of Main Panel	-NA-	-NA-	-NA
	• Location of Repeater Panel	-NA-	-NA-	-NA
	• Alternate source of power	-NA-	-NA-	-NA

	• Hooters' Location	-NA-	-NA-	-NA-
8.	MOEFA	-NA-	-NA-	-NA-
9.	Public Address System	-NA-	-NA-	-NA-
10.	Automatic Sprinkler System			
	• Basement	-NA-	-NA-	-NA-
	• Ground & Upper Floors	-NA-	-NA-	-NA-
	• Sprinkler above false ceiling	-NA-	-NA-	-NA-
11.	Internal Hydrants			
	• Size of riser/down-comer	-NA-	-NA-	-NA-
	• Number of hydrants per floor	-NA-	-NA-	-NA-
	• Hose Box	-NA-	-NA-	-NA-
12.	Yard Hydrants			
	• Total number of hydrants	-NA-	-NA-	-NA-
	• Hose Box	-NA-	-NA-	-NA-
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main Pump	-NA-	-NA-	-NA-
	➤ Head of Main pump	-NA-	-NA-	-NA-
	➤ Number of main pumps	-NA-	-NA-	-NA-
	➤ Jockey Pump out put	-NA-	-NA-	-NA-
	➤ Jockey pump head	-NA-	-NA-	-NA-
	➤ Standby Pump out put	-NA-	-NA-	-NA-
	➤ Standby Pump Head	-NA-	-NA-	-NA-
	➤ Auto Starting/Manual Stopping	-NA-	-NA-	-NA-
	➤ Pump House Access	-NA-	-NA-	-NA-
	• Terrace level			
	➤ Discharge of pump	450lpm	2 x 450lpm	MR
	➤ Head of the pump	40m	40m	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14.	Captive Water Storage for fire fighting			
	• Underground tank capacity	-NA-	-NA-	-NA-
	➤ Draw-off connection	-NA-	-NA-	-NA-
	➤ Fire service inlet	-NA-	-NA-	-NA-
	➤ Access to tank	-NA-	-NA-	-NA-
	• Overhead Tank capacity	10,000ltr	20,000ltr	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	• Pressurization of Lift Shaft	-NA-	-NA-	-NA-
	• Pressurization of Lift lobby	-NA-	-NA-	-NA-
	• Communication In lift Car	-NA-	-NA-	-NA-
	• Fireman's Grounding Switch	-NA-	-NA-	-NA-
	• Lift Signage	-NA-	-NA-	-NA-
17.	Standby power supply	-NA-	-NA-	-NA-
18.	Refuge Area.			
	➤ Total Area	-NA-	-NA-	-NA-
	➤ Location	-NA-	-NA-	-NA-
19.	Fire Control Room			
	• Detector System Panel	-NA-	-NA-	-NA-
	• Flow Switch Panel	-NA-	-NA-	-NA-
	• PA System Panel	-NA-	-NA-	-NA-
	• Battery backup	-NA-	-NA-	-NA-
	• Building Floor Plans	-NA-	-NA-	-NA-


Special Fire Protection System for Protection of special Risks, if any:	-NA-	-NA-	-NA
---	------	------	-----


Accordingly, the fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.


In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F.6/DFS/MS/School/WZ/2022/290 dated 16.03.2022 is recommended for renewal under rule 37 of the Delhi Fire Service rules 2010.


Signature of the Inspecting Officer
Name Ajay Kumar Sharma
Designation ADO(Rohini)


~~DO (NW)~~


10/03/2025


24/03/2025



10/3

1086 NW
10/3/2025


cfo
11/01/2025
Director


AO/DO

FS letter to put up for kind perusal
and Signature please.


12/3/25
Director


12/3/25