

## GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001

No.F6/DFS/MS/2025/ School/ 187

Dated: 21/02/2025

## **FIRE SAFETY CERTIFICATE**

DIRECTOR Delhi Fire Service

## Copy to:-

1. The Commissioner, MCD, Civic Centre, New Delhi.

2. The Principal, Govt. Girls Ser. Sec. School, Quresh Nagar, Idgah Road, Delhi.

3. Director of Education, Govt. of NCT, Delhi.

## Conditions for the validity of fire safety certificate

- All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
- 2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.

3. The trained fire fighting staff should be available round the clock.

- 4. The compliance with regards to electrical installation, structural stability, set back area, occupancy and any deviation in construction etc. shall be verified from authority concerned.
- 5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
- 6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on <a href="https://www.dfs.delhigovt.nic.in">www.dfs.delhigovt.nic.in</a>
- 7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
- 8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry".

INSPECTION REPORT 1. Name & address of the building:- Govt. Girls Ser. Sec. School at Quresh Nagar, Idgah Road, Delhi.( ID no. 1208027) Educational Group B-I, Gr.+01 Upper Floor 2. Type of occupancy:-3. Type of case:-Renewal F6/DFS/MS/2022/School/180 date 17/02/22. 4. Details of previous NOC:-5. Fire safety directives No.-N/A 6. Date of inspection:-31 /01/25 7. Name of the inspecting officer:-Sh. Ravinder Singh (ADO/CC) 8. Name & designation of officer From the building side:-Sh. P.C Joshi, HOS 9. Year of construction:-2014 10. Applicant's letter No:-GGSSS/QN/2024-25/1618 dated 30/12/24. Old Case S.No. Minimum Standards on fire Provided at site Remarks Requirement Prevention and fire safety as per N-1 & MR/NMR U/R 33 N-6 1. Access to Building 1) Road width 06 mtr. 06 mtr. MR 2) Gate width NA 3.5 mtr. NA 3) Width of internal road NA NA NA 2. Number, Width Type & Arrangement of Exits A. Number of staircases 1. Upper floors 01 01 MR 2. Basements N/A N/A N/A B. Width of staircase 1. Upper floors 1.50 mtr 1.50 mtr. MR 2. Basements N/A N/A N/A C. Protection of exits 1. Fire check door N/A N/A N/A 2. Pressurization N/A N/A N/A D. No. of continuous 01 01 MR staircase to terrace E. Width of corridor 2.0 mprovided MR F. Door size 1 mtr. 1 mtr. MR Compartmentation 3. 1) Fire check door N/A N/A N/A 2) Sealing of electrical shafts N/A N/A N/A 3) Fire rating of shaft door N/A N/A N/A

4) Water curtain N/A N/A N/A 5) Fire Dampers N/A N/A N/A Smoke Management System 4. 1) Basements N/A N/A N/A 2) Upper floors 12 ACPH Natural MR Fire Extinguishers 5. 1) Total numbers 06 Nos. 08 Nos. MR 2) Types ABC & CO2 ABC, CO2 & W.CO2 MR 3) ISI marking Required Provided MR First-Aid Hose Reel 6.

NIV

	1) I Ottal Manne or or other	N/A	N/A	N/A			
	floor 2) Length of hose reel hose	N/A	N/A	N/A			
	3) Nozzle diameter	N/A	N/A	N/A			
	Automatic Fire Detection & Al		534 576 57 1965	INA			
7	1) Type of detectors	N/A	N/A	N/A			
	2) Location of main panel	N/A	N/A	N/A			
	3) Location of repeater panel	N/A	N/A	N/A			
		N/A	N/A	N/A			
	4) Alternate source of power	N/A	N/A	N/A			
	5) Hooter's Location	N/A	N/A	N/A			
	MOEFA		N/A	N/A			
)	Public Address System	N/A	IVA	IN/A			
0.	Automatic Sprinkler System	NT/A	NT/A	NT/A			
	1) Basement	N/A	N/A	N/A			
	2) Upper floors	N/A	N/A	N/A			
	Sprinkler above false ceiling	N/A	N/A	N/A			
11	Internal Hydrants		37/1	27/4			
	1) Size of riser/down-comer	N/A	N/A	N/A			
	2) Number of hydrants per floor	N/A	N/A	N/A			
	3) Hose box	N/A	N/A	N/A			
12.	Yard Hydrants						
	1) Total number of hydrants	N/A	N/A	N/A			
	2) Hose box	N/A	N/A	N/A			
13.	Pumping Arrangement						
J.	1) Ground level	N/A	N/A	N/A			
	a) Discharge of main pump	N/A	N/A	N/A			
	b) Head of main pump	N/A	N/A	N/A			
	c) Number of main pump	N/A	N/A	N/A			
	d) Jockey pump out put	N/A	N/A	N/A			
1	e) Jockey pump head	N/A	N/A	N/A			
	f) Stand by pump output	N/A	N/A	N/A			
	g) Stand by pump head	N/A	N/A	N/A			
	h) Auto starting/Manual stopping	N/A	N/A	N/A			
	2) Terrace level			200 MAN (2007)			
	a) Discharge of pump	N/A	N/A -	N/A			
	b) Head of pump	N/A	N/A	N/A			
	c) Power supply	N/A	N/A	N/A			
	d) Auto starting of pump	N/A	N/A	N/A			
14.	. Captive Water Storage for Fire Fighting						
	Under ground tank     capacity	N/A		N/A			
	a) Draw-off connection	N/A	N/A	N/A			
	b) Fire service inlet	N/A	N/A	N/A			

	c) Access to tank	N/A	N/A	N/A
	d) Over head tank capacity	N/A	N/A	N/A
15.	Exit Signage.	N/A	provided	N/A
16.	Provision of Lifts.	* =====		
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	N/A	N/A	N/A
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A N/A
20.	Special Fire Protection System for Protection of special Risk, if any:			

The fire protection system provided in the school building were tested, checked at random and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, if agreed, we may renew the FSC issued vide letter No. F6/DFS/MS/2022/School/180 dated 17/02/22, under Rule 35(6) of the Delhi Fire Service rules 2010,

Signature of the Inspecting Officer

Name:-Ravinder Singh Designation:-ADO (CC)

Dare (NOS)

KIV P

C.F.O

Clarfy either both files are related to one comprise or not

96 yes, than make only one bile & also club one 10 FSC. When

Duces in so

Live

12 Jan 132