

c58

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F.6/DFS/MS/2025/School/WZ/135

Dated: 11/02/2025

**FIRE SAFETY CERTIFICATE**

Certified that the **Govt. Girls Senior Secondary School, Sector-25, Rohini, Delhi-110085. (School Id-1413340)**, comprised of **Ground + 03 upper floors** has already been issued FSC by this department vide letter No. **F.6/DFS/MS/2022/School/WZ/289 dated 16.03.2022**. The premises was re-inspected by the officer concerned of this department on **22.01.2025** in the presence of **Mrs. Seemakshi Tomar (Head of School)** and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises fit for occupancy class "**Group B Educational**" with effect from 11/02/2025 for a period of **three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subjected to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 11/02/2025 at New Delhi by

  
(Atul Garg)  
**DIRECTOR**  
Ph; 011-23414000

**Copy to:-**

1. The Director of Education, Old Secretariat, Delhi
2. The Principal, Govt. Girls Senior Secondary School, Sector-25, Rohini, Delhi-110085. (School Id-1413340).

**Conditions for the validity of fire safety certificate:**

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection.
3. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of firefighting system.
5. The owner/ occupier shall submit a declaration **every year** in **Form 'K'** [sub rule (2) of Rule 38] provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [http://delhi.gov.in/wps/wcm/connect/doit\\_fire/FIRE/Home/Forms](http://delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms)
6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction (Clause 2.9.2 of UBBL-2016) or Alteration (Clause 1.4.3 of UBBL-2016), if any.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in **Form 'J'** [sub rule (1) of Rule 37] along with a copy of this Certificate, **six months** prior to its expiry."



# INSPECTION REPORT

1. Name & address of the building	Govt. Girls Senior Secondary School, Sector-25, Rohini, Delhi-110085. (School Id-1413340)			
2. Type of Occupancy	Educational			
3. Type of Case	Renewal ( <b>Ground + 03 upper floors</b> )			
4. Details of Previous NOC	F.6/DFS/MS/2022/School/WZ/289 dated 16.03.2022.			
5. Fire Safety directives letter No	NBC Part-IV			
6. Date of inspection	22.01.2025			
7. Name of Inspecting Officer	Sh. Ajay Kumar Sharma (ADO Rohini)			
8. Name and designation of officers From the building side	Mrs. Seemakshi Tomar (Head of School)			
9. Year of Construction	2018			
10. Applicant's letter No.	OD No.11281 dated 10.01.2025.			
S. No	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1.	<b>Access to building</b>			
	• Road width	Accessible	Accessible	MR
	• Gate width	Accessible	4.5m	MR
	• Width of internal road	-NA-	-NA-	NA-
2.	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	<b>a. Number of staircases</b>			
	• Upper Floors	02nos.	02nos.	MR
	• Basements	-NA-	-NA-	NA-
	<b>b. Width of staircases</b>			
	• Upper Floor	1.5m	Provided	MR
	• Basements	-NA-	-NA-	NA-
	<b>c. Protection of exits</b>			
	• Fire check door	-NA-	-NA-	NA-
	• Pressurization	-NA-	-NA-	NA-
	<b>d. No. of continuous staircases to terrace</b>	-NA-	-NA-	NA-
	<b>e. Width of Corridor</b>	-NA-	-NA-	NA-
	<b>f. Door Size</b>	1.0m	Provided	MR
3.	<b>Compartmentation</b>			
	• Fire check door	-NA-	-NA-	NA-
	• Sealing of electrical shafts	-NA-	-NA-	NA-
	• Fire Rating of shaft door	-NA-	-NA-	NA-
	• Water Curtain	-NA-	-NA-	NA-
	• Fire Dampers	-NA-	-NA-	NA-
4.	<b>Smoke Management System</b>			
	a) Basements	-NA-	-NA-	NA-
	b) Upper floors	12 a/c per hour	Natural ventilated	MR
5.	<b>Fire Extinguishers</b>			
	• Total numbers	50nos.	Provided	MR
	• Types	ABC/CO2	ABC/CO2	MR
	• IS marking	ISI marked	Yes	MR
6.	<b>First-Aid Hose Reels</b>			
	• Total numbers on each floor	01nos.	Provided	MR
	• Length of hose reel hose	30mm	Provided	MR
	• Nozzle diameter	5m	Provided	MR
7.	<b>Automatic fire detection and alarming system</b>			
	a) Type of detectors	-NA-	-NA-	NA-



	b) Location of Main Panel	-NA-	-NA-	-NA-
	c) Location of Repeater Panel	-NA-	-NA-	-NA-
	d) Alternate source of power	-NA-	-NA-	-NA-
	e) Hooters' Location	-NA-	-NA-	MR
8.	MOEFA	Required	Provided	-NA-
9.	Public Address System	-NA-	-NA-	-NA-
10.	Automatic Sprinkler System	-NA-	-NA-	-NA-
	• Basement	-NA-	-NA-	-NA-
	• Ground & Upper Floors	-NA-	-NA-	-NA-
	• Sprinkler above false ceiling	-NA-	-NA-	-NA-
11.	Internal Hydrants	-NA-	Provided	-NA-
	• Size of riser/down-comer	-NA-	01nos.	-NA-
	• Number of hydrants per floor	-NA-	01nos.	-NA-
	• Hose Box	-NA-	-NA-	-NA-
12.	Yard Hydrants	-NA-	-NA-	-NA-
	• Total number of hydrants	-NA-	-NA-	-NA-
	• Hose Box	-NA-	-NA-	-NA-
13.	Pumping Arrangements	-NA-	-NA-	-NA-
	• Ground Level	-NA-	-NA-	-NA-
	➤ Discharge of main Pump	-NA-	-NA-	-NA-
	➤ Head of Main pump	-NA-	-NA-	-NA-
	➤ Number of main pumps	-NA-	-NA-	-NA-
	➤ Jockey Pump out put	-NA-	-NA-	-NA-
	➤ Jockey pump head	-NA-	-NA-	-NA-
	➤ Standby Pump out put	-NA-	-NA-	-NA-
	➤ Standby Pump Head	-NA-	-NA-	-NA-
	➤ Auto Starting/Manual Stopping	-NA-	-NA-	-NA-
	➤ Pump House Access	-NA-	-NA-	-NA-
	Terrace level	-NA-	-NA-	-NA-
	➤ Discharge of pump	450lpm	2 x 450lpm	MR
	➤ Head of the pump	40m	40m	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14.	Captive Water Storage for fire fighting	-NA-	50,000ltr	-NA-
	• Underground tank capacity	-NA-	-NA-	-NA-
	➤ Draw-off connection	-NA-	-NA-	-NA-
	➤ Fire service inlet	-NA-	-NA-	-NA-
	➤ Access to tank	-NA-	-NA-	-NA-
	• Overhead Tank capacity	10,000ltr	Provided	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.	-NA-	-NA-	-NA-
	• Pressurization of Lift Shaft	-NA-	-NA-	-NA-
	• Pressurization of Lift lobby	-NA-	-NA-	-NA-
	• Communication In lift Car	-NA-	-NA-	-NA-
	• Fireman's Grounding Switch	-NA-	-NA-	-NA-
	• Lift Signage	-NA-	-NA-	-NA-
17.	Standby power supply	-NA-	-NA-	-NA-
18.	Refuge Area.	-NA-	-NA-	-NA-
	➤ Total Area	-NA-	-NA-	-NA-
	➤ Location	-NA-	-NA-	-NA-

20.	<b>Fire Control Room</b>			
	• Detector System Panel	-NA-	-NA-	-NA-
	• Flow Switch Panel	-NA-	-NA-	-NA-
	• PA System Panel	-NA-	-NA-	-NA-
	• Battery backup	-NA-	-NA-	-NA-
	• Building Floor Plans	-NA-	-NA-	-NA-
<b>Special Fire Protection System for Protection of special Risks, if any:</b>				

Accordingly, the fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F.6/DFS/MS/2022/School/WZ/289 dated 16.03.2022 is recommended for renewal under rule 37 of the Delhi Fire Service rules 2010.

Signature of the Inspecting Officer  
 Name Ajay Kumar Sharma  
 Designation ADO(Rohini)

D.B Mukherjee  
 DO (NW)

[Signature]  
 04/02/2025

Dy Cb (WZ) - mIR

[Signature]  
 6/24/2025

Director [Signature]  
 7/2/25

[Signature]  
 7/2/25

FF letter to put up for kind  
 perusal and signature please.

Director [Signature]  
 7/2/25

[Signature]  
 7/2/25

Copy to...  
 Dated... 6/2/25