

C20

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/School/WZ/2025/ 86

Dated: 30/01/2025

FIRE SAFETY CERTIFICATE

Certified that the Govt. Girls Sr. Sec. School No. 1, Located at Shakurpur, New Delhi - 110034. (School ID-1411125), comprised of Ground + 01 Upper Floors, owned/Occupied by Govt. Girls Sr. Sec. School No.1, was issued FSC vide letter No F6/DFS/MS/School/WZ/2022/83 dated 01/02/2022. The premises was re - inspected by the officer concerned by this department on 22/01/2025, in the presence of Smt. Anjali Chillar and found that the building/premises (Ground + 01 Block) have deemed complied with fire prevention and fire safety requirements in accordance with D.O.E. Circular No. 3298-3398 dated 01/03/2011 and that the building / premises is fit for the occupancy class "Educational" Group B (Ground + 01 Block only) with effect from 30/01/2025 for a period of three years, subject to compliance of the conditions under rule 38 of the Delhi fire Service Rules, 2010.

Issued on 30/01/2025 at New Delhi.

(Atul Garg)
Director

Copy to:

1. The Principal, Govt. Girls Sr. Sec. School No. 1, Located at Shakurpur, New Delhi - 110034. (School ID-1411125), Email ID:-hos1411125@gmail.com
2. Director of Education, GNCT of NCT of Delhi, Old Secretariat.

Conditions for the validity of FSC:-

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing department shall always be permitted and followed.
7. The owner /occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37) along with copy of the certificate, six months prior to its expiry.

INSPECTION REPORT

1.	Name & address of the building	Govt. Girls Sr. Sec. School No. 1, Located at Shakurpur, New Delhi - 110034. (School ID-1411125)
2.	Type of Occupancy	Educational (Ground + 01 Upper Floor)
3.	Type of Case	Renewal
4.	Details of previous NOC	F6/DFS/MS/School/WZ/2022/83 dated 01/02/2022
5.	Fire Safety directives letter No	Nil
6.	Date of inspection	22/01/2025
7.	Name of the Inspecting Officers	Sarabjeet Singh ADO (MN)
8.	Name and designation of officers from the building side	Smt. Anjali Chillar (H. O. S.)
9.	Year of Construction	2021-22 (As per previous Inspection Report dtd.- 24/01/2022)
10.	Applicant's letter No.	Email dated 16/01/2025.

The said school building comprised of Ground + 01 Upper Floor, was issued FSC vide letter no. F6/DFS/MS/School/WZ/2022/83 dated 01/02/2022.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	As per Rule 35 (6) DFS Rule 2010	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	6m	09m Provided	MR
	• Gate width	4.5 m	3.20m Provided	MR(Old case)
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	2	Provided	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	1.5m	1X1.60m, 1X1.55m	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	1.5m	Provided	MR
	f. Door Size	1.m	Provided	MR
3	Compartmentation.			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA
5	Fire Extinguishers			
	• Total numbers	23 nos.	Provided	MR
	• Types	CO ₂ , ABC type	Provided	MR
	• IS marking	ISI marked	Provided	MR
6	First-Aid Hose Reels.			
	• Total numbers on each floor	NA	NA	NA
	• Length of hose reel hose	NA	NA	NA
	• Nozzle diameter	NA	NA	NA

7	Automatic fire detection and alarming system.			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8	MOEFA	NA	NA	NA
9	Public Address System.	NA	NA	NA
10	Automatic Sprinkler System.			
	• Basement	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants			
	• Size of riser/down-comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12	Yard Hydrants.			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13	Pumping Arrangements.			
	• Ground Level			
	➤ Discharge of main Pump	NA	NA	NA
	➤ Head of Main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey Pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/ Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	NA	NA	NA
	➤ Head of the pump	NA	NA	NA
	➤ Power Supply	NA	NA	NA
	➤ Auto Starting of pump	NA	NA	NA
14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	NA	NA	NA
15	Exit Signage.	NA	NA	NA
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17	Standby power supply	NA	NA	NA
18	Refuge Area.			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA

N/13

19	Fire Control Room			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Battery backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of minimum standards of fire prevention and fire safety measures as requirements as per D.O.E Circular No. 3298-3398 dated 01/03/2011, renewal of Fire Safety Certificate issued vide letter no F6/DFS/MS/School/WZ/2022/83 dated 01/02/2022, is recommended.

Dy. Commr (2)

SJP
24/11/2025

Signature of the Inspecting Officer
Sarabjeet Singh ADO (MN)

HPD/nm
10/1/2025

SJP
24/11/2025

561-WD
24.01.25

CFD
Ward
27/01/2025
Director
28/11/25

Harj mr

Sir P.T is put up for your kind personal & signature please.

SJP
29/11/2025

Director
M