



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**




No.F6/DFS/MS/School/SZ/2025/ 1146

Dated: 16/09/2025

**FIRE SAFETY CERTIFICATE**

Certified that the Govt. Girls Sr. Sec. School No.2 located at Molarband, New Delhi (School ID no. 1925053), comprised of two blocks: Ground + 03 upper floors each, was granted Fire Safety Certificate (FSC) by this department vide letter no. F6/DFS/MS/School/2020/SZ/279 dated 14.08.2020 & F6/DFS/MS/School/SZ/2022/1102 dated 03.10.2022. The school building was re-inspected by Assistant Divisional Officer (M. Road) from this department on 09.09.2025 in the presence of Manju Gautam (Principal) and found that the building/premises has complied with the fire prevention and fire safety requirements in accordance with Rule 33 of Delhi Fire Service Rules, 2010. Accordingly, the premises/building is comprised of Two blocks (Ground + 03 upper floors each) is fit for occupancy of Group B "Educational Building" with effect from ...16/09/2025 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to conditions under Rule 38 of Delhi Fire Service Rules, 2010 printed below.

Issued on...16/09/2025 at New Delhi by.

  
(Virendra Singh)  
Chief Fire Officer  
o/c 16/9/25

Copy to:-

1. The Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, Delhi.
2. The Principal, Govt. Girls Sr. Sec. School No.2 located at Molarband, New Delhi (School ID no. 1925053).

Conditions for the validity of Fire Safety Certificate:-

1. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form 'J' [sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry
2. All the means of escape shall be kept free of all the type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
6. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).

# INSPECTION REPORT

1	Name and address of the building:		Govt. Girls Sr. Sec. School No.2 located at Molarband, New Delhi-44. (School ID no. 1925053).		
2	Building is comprised of		Comprised of Two blocks Ground + 03 upper floors each		
3	Type of occupancy		Educational Building (Group –B)		
4	Type of case:		Renewal		
5	Details of previous FSC:		F6/DFS/MS/School/2020/SZ/279 dated 14.08.2020 for (G+3) old block F6/DFS/MS/School/SZ/2022/1102 dated 03.10.2022 for (G+3) New block		
6	Fire safety directives no.:		UBBL/NBC –Part IV-2016		
7	Date of inspection:		09.09.2025		
8	Name of the inspecting officer:		ADO Rajesh Kumar Shukla (M. Road)		
9	Name and designation of the officer from the building side:		Mrs. Manju Gautam (Principal)		
10	Year of construction:		2016 & 2022		
11	Reference letter no.:		Outdoor diary no.729 dated 17.04.2025		
S.No	Minimum Standards on fire Prevention and fire safety requirements U/R 33		Requirement s as per Rule 35 (6)	Provide at site	Remarks MR/NMR
1	Access to Building				
	A	Road width	6.0 mtrs.	6.0 mtrs.	MR
	B	Gate width	NA	NA	NA
	C	Width of internal roads	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits				
	A	No. of staircase:			
		a) Upper floor	02 nos. each block	Old block- 02 nos. New block- 04 nos.	MR
		b) Basements	NA	NA	NA
	B	Width of the staircase:			
		a) Upper floor	1.50 m each block	Old block- 1.60 m each New block- 1.70 m each	MR
		b) Basements	NA	NA	NA
	C	Protection of exits			
		a) Fire check door	NA	NA	NA
		b) Pressurization	NA	NA	NA
	D	No. of continuous staircase to terrace:	04 nos.	Provided	MR
	F	Width of the corridor	1.5 mtrs each block	Provided	MR
	E	Door size	1.0 mtrs. (for class room)	1.0 mtrs. (for class room)	MR
3	Compartmentation:				
	A	Fire check doors	NA	NA	NA
	B	Sealing of electrical shafts	NA	NA	NA
	C	Fire rating of shaft doors	NA	NA	NA
	D	Water curtain	NA	NA	NA
	E	Fire dampers	NA	NA	NA
4	Smoke Management System:				
	A	Upper floors	NA	NA	NA
	B	Basements	NA	NA	NA
5	Fire Extinguishers				
	A	Total numbers	50 nos.	116 nos.	MR
	B	Types	CO <sub>2</sub> & ABC	CO <sub>2</sub> & ABC	MR
	C	ISI marking	Required	Provided	MR

6	First Aid Hose reel				
	A	Total no. at each floor	Old block 1 no. New block- 5 nos.	Provided	MR
	B	Length of hose reel	30 m	Provided	MR
	C	Nozzle diameter	5 mm	Provided	MR
7	Automatic Fire Detection and Alarm System (ADAS)				
	A	Type of detectors	NA	NA	NA
	B	Location of main panel	NA	NA	NA
	C	Location of repeater panel	NA	NA	NA
	D	Alternate power source	NA	NA	NA
	E	Hooter's location	NA	NA	NA
8	MOEFA		NA	NA	NA
9	Public Address System		NA	Provided	NA
10	Automatic Sprinkler System				
	A	Basement	NA	NA	NA
	B	Upper floor	NA	NA	NA
	C	Sprinklers above false ceiling	NA	NA	NA
11	Internal Hydrants				
	A	Size of the riser/down comer	NA	NA	NA
	B	No. Of hydrants per floor	NA	NA	NA
	C	Hose box	NA	NA	NA
12	Yard Hydrants				
	A	Total no. of hydrants	NA	NA	NA
	B	Hose box	NA	NA	NA
13	Pumping Arrangements				
	A	Ground Level			
		a) Discharge of main pump	NA	NA	NA
		b) Head of main pump	NA	NA	NA
		c) Number of main pump	NA	NA	NA
		d) Discharge of jockey pump	NA	NA	NA
		e) Head of jockey pump	NA	NA	NA
		f) Discharge of standby pump	NA	NA	NA
		g) Head of standby pump	NA	NA	NA
		h) Auto starting/ manual stopping	NA	NA	NA
	B	Terrace Level			
		a) Discharge of terrace pump	450 LPM each	02 nos. of 450 LPM each	MR
		b) Head of terrace pump	40 mtrs each	Provided	MR
		c) Alternate power supply	Required	Provided	MR
		d) Auto starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting				
	A	Underground tank capacity	NA	NA	NA
	B	Draw off connection	NA	NA	NA
	C	Fire service inlet	NA	NA	NA
	E	Access to tank	NA	NA	NA
	D	Overhead tank capacity	NA	NA	NA
15	Exit Signage		10,000 litters each block	Provided	MR
16	Provision of lift				
	A	Pressurization of lift shaft	NA	NA	NA
	B	Pressurization of lift lobby	NA	NA	NA
	C	Communication in lift car	NA	NA	NA
	D	Fireman switch	NA	NA	NA
	E	Lift signage	NA	NA	NA
17	Standby Power Supply		NA	NA	NA


<b>18</b>	<b>Refuge Area</b>			
<b>A</b>	location	NA	NA	NA
<b>B</b>	Total area	NA	NA	NA
<b>19</b>	<b>Fire Control Room</b>			
<b>A</b>	Fire detection system panel	NA	NA	NA
<b>B</b>	Flow switch panel	NA	NA	NA
<b>C</b>	P A system panel	NA	NA	NA
<b>D</b>	Battery backup	NA	NA	NA
<b>E</b>	Building floor plan	NA	NA	NA
<b>20</b>	<b>Special Fire Protection for special risk if any</b>			
				NA

**Meeting Requirement (MR), Not Meeting Requirement (NMR), Not Applicable (NA), Provided But Not Functional (PNF).**

**Note:** The School building is comprised of Two separate blocks which have earlier has been issued separate FSC vide letter no. F6/DFS/MS/School/2020/SZ/279 dated 14.08.2020 & F6/DFS/MS/School/SZ/2022/1102 dated 03.10.2022. However during this single Fire Safety Certificate (FSC) has been considered for the entire School.

The fire protection systems provided in the building were tested checked and found properly functional at the time of inspection.

In view of the deemed compliance of the minimum standards on fire prevention and fire safety required under the rule, the FSC issued vide letter no. F6/DFS/MS/School/2020/SZ/279 dated 14.08.2020 & F6/DFS/MS/School/SZ/2022/1102 dated 03.10.2022, **renewal under rule 37 of the Delhi Fire Service Rule 2010 is recommended.**


  
Signature of the Inspecting Officer  
Name Rajesh Kumar Shukla  
Designation ADO (M. Road)

DO (SD)

  
10/9/2025

Principal Director

CFD to SSM.

  
12/09/25



ADO (M.R.)

  
15/9.

F1 is first pl

  
15/9

  
16/9/2025

