

0/92



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/2025/School/ 807
To

Dated: 12 / 11 /2025

The Principal
Govt. Sarvodaya Kanya Vidhyalaya,
Badli, Delhi-110042.

Sub: Regarding issuance of fire safety certificate in r/o Govt. Sarvodaya Kanya Vidhyalaya
(School ID No- 1310034) located at Badli, Delhi-110042 .

Sir,

Please refer to your letter No. SKB/BALI/2025/960 dated 25/09/2025 on the subject cited above. In this connection this is to inform you that the above mentioned site was visited by the officer concerned of this department on 01/11/2025 to verify the fire safety measures issued vide NBC Part-IV/D.O.E and observed that the building was comprised of 05 Blocks –A, B, C, D & E Blocks, I.e. A Block- Ground + 02 Upper floors, B, C, D Blocks- Ground + first floor & E Block- (New Building) Ground & 03 upper floors only. At the time of inspection Smt. Uma (Principal) was also present at site. During the course of inspection observations/ shortcomings made are as under:-

1. Electrical panel below at 'A' block ground floor needs to be removed/shifted in a safer place or covered by fire check door.
2. Hose reel hose is provided but not functional some hose reel nozzles found missing.
3. Internal hydrant is provided but not functional and damaged condition.
4. Terrace level fire fighting pump capacity of 450lpm is provided but not functional and badly leakage/damaged condition.
5. One inspection ladder also required for overhead water storage tank for inspection purpose in (G+2) A block & (G+3) E block.
6. Standby power supply is not provided.
7. The alternate staircase of new building at ground level has storage of plastic chair and flammable items below staircase needs to be removed.

Keeping in view of above, issuance of Fire Safety Certificate cannot be considered at this stage & rejected. You are requested to rectify the above mentioned shortcomings under intimation to this department; till such time running of school building is at your own risk & responsibility.

Yours faithfully


(S.K. Dua)

Dy. Chief Fire Officer
Delhi Fire Service



Copy to:-

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 110054.