



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

C-59
C-59
C-59

No: F.6/DFS/MS/2025/WZ/793

Dated: 04/11/2025

To,

The Principal,
Govt. S.K.V,
S.P. Road, Nangloi,
Delhi-110041.

Sub:- Renewal of Fire Safety Certificate in respect of Govt. S.K.V. (ID- 1617013)
located at S.P. Road, Nangloi, Delhi- 110041.

Sir,

This has reference to e mail id dated 10/09/2025 on the subject cited above. In this connection, it is to inform you that the inspection of above said school building has been carried out by officer concerned of this department on 17.10.2025 to see the compliance of the requisite fire safety measures. Ms. Seema Sharma (Principal) was present at the time of inspection.

During the course of inspection it was observed that the school building is comprised of 03 Blocks (A Block- G+2 & B, C Blocks (G+1). Your request for renewal of FSC is rejected as the following shortcomings were observed:-

1. First aid hose reels found provided but not functional and hose reel nozzle found missing at some places.
2. Terrace level pumps found provided but not functional.
3. Overhead tank of 10,000 ltrs capacity found empty.

You are advised to rectify the above-mentioned shortcoming for taking further action as necessary for renewal of Fire Safety Certificate.

Yours Faithfully

(S.K. Dua)

Dy. Chief Fire Officer
West Zone

Copy to :-

1. Director of Education, Govt. Of NCT of Delhi, Old Secretariat, New Delhi.