




No. F6/DFS/MS/School/NDZ/2025/1067

Dated: 25/08/2025

**FIRE SAFETY CERTIFICATE**

Certified that the M/s Govt. Sarvodya Vidyalaya located at Badarpur Khadar, Delhi-110090, comprised of ground plus one upper floor only, owned / occupied by M/s Govt. Sarvodya Vidyalaya was issued FSC vide letter No. F6/DFS/MS/School/2022/NDZ/428 dated 19/04/2022. The school building has complied with the fire prevention and fire safety requirements in accordance with the Circular No.F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01/03/2011 issued by the Director of Education and re-inspected by the officer concerned of this department on 19/08/2025 in presence of Mr. Avdhesh (HOS) of the school and that the school building is fit for occupancy class "Educational Building" (Group - B) with effect from 25/08/2025 for a period of **three years** in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rule 2010 & also conditions printed bellow.

Issued on 25/08/2025 at New Delhi by.

  
25/8/2025  
VIRENDRA SINGH  
CHIEF FIRE OFFICER  
DELHI FIRE SERVICE

**Copy to: -**

1. The Dy. Director of Education, D - Block, Anand Vihar, Delhi - 110092.
2. The Principal, M/s Govt. Sarvodya Vidyalaya, Badarpur Khadar, Delhi-110090.

**Conditions for the validity of Fire Safety Certificate**

1. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry
2. All the means of escape shall be kept free of all the type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipment's and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the firefighting equipment's shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc. may be got verified from the authorities concerned.
6. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).



## INSPECTION REPORT

01.	Name & address of the building	M/s Govt. Sarvodya Vidyalaya located at Badarpur Khadar, Delhi-110090.			
02.	Building is comprised of	Ground plus one floor only.			
03.	Type of occupancy	Educational Building			
04.	Type of case	Renewal			
05.	Details of previous FSC	F6/DFS/MS/School/2022/NDZ/428 dated 19/04/2022.			
06.	Fire safety directives letter no.	F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01/03/2011			
07.	Date of inspection	19.08.2025.			
08.	Name of the inspecting officers	Yashwant Singh Meena ADO (L.N)			
09.	Name of the designation of officer from the building side	Mr. Avdhesh (HOS)			
10.	Year of construction	2015			
11.	Applicant's letter no.	Outdoor dairy no. 3685 dated 11/07/2025			
S.No	Minimum standard of fire prevention and fire safety U/R 33	Circular Requirement	Provided at site	Remarks MR/NMR	
01.	<b>Access to Building:</b>				
	A	Road width	6.0 mtrs.	06 mtrs.	MR
	B	Gate width	N/A	N/A	N/A
	C	Width of internal road	N/A	N/A	N/A
02.	<b>Number, Width, Type and Arrangement of Exits:</b>				
	A	Number of staircases			
	a	Upper floor	03 no.	03 nos.	MR
	C	Basement	N/A	N/A	N/A
	B	Width of staircases			
	a	Upper floor	1.50 mtrs.	1.50 mtrs. each	MR
	C	Basement	N/A	N/A	N/A
	C	Protection of exits			
	a	Fire check door	N/A	N/A	N/A
	b	Pressurization	N/A	N/A	N/A
	D	No. of continuous staircases to terrace	02 no.	02 nos.	MR
	E	Width of corridor	1.50 mtrs.	1.50 mtrs.	MR
	F	Door size	1.0 mtrs.	1.0 mtrs.	MR
03.	<b>Compartmentation:</b>				
	A	Fire check door	N/A	N/A	N/A
	B	Sealing of electrical shafts	N/A	N/A	N/A
	C	Fire rating of shaft door	N/A	N/A	N/A
	D	Water curtain	N/A	N/A	N/A
	E	Fire dampers	N/A	N/A	N/A
04.	<b>Smoke Management System:</b>				
	A	Basement	N/A	N/A	N/A
	B	Upper floor	N/A	N/A	N/A



<b>05.</b>	<b>Fire Extinguisher:</b>				
	<b>A</b>	Total numbers	08 nos.	24 nos.	MR
	<b>B</b>	Types	ABC/CO <sub>2</sub>	ABC/CO <sub>2</sub>	MR
	<b>C</b>	ISI marking	ISI Marked	ISI Marked	MR
<b>06.</b>	<b>First-Aid-Hose Reel:</b>				
	<b>A</b>	Total numbers of each floor	N/A	N/A	N/A
	<b>B</b>	Length of hose reel hose	N/A	N/A	N/A
	<b>C</b>	Nozzle diameter	N/A	N/A	N/A
<b>07.</b>	<b>Automatic Fire Detection and Alarming System:</b>				
	<b>A</b>	Type of detectors	N/A	N/A	N/A
	<b>B</b>	Location of main panel	N/A	N/A	N/A
	<b>C</b>	Location of repeater panel	N/A	N/A	N/A
	<b>D</b>	Alternate source of power	N/A	N/A	N/A
	<b>E</b>	Hooters	N/A	N/A	N/A
<b>08.</b>	<b>MOEFA:</b>		N/A	N/A	N/A
<b>09</b>	<b>Public Address System:</b>		N/A	Provided	MR
<b>10.</b>	<b>Automatic Sprinkler System:</b>				
	<b>A</b>	Basement	N/A	N/A	N/A
	<b>B</b>	Upper floor	N/A	N/A	N/A
	<b>C</b>	Sprinkler above false ceiling	N/A	N/A	N/A
<b>11.</b>	<b>Internal Hydrants:</b>				
	<b>A</b>	Size of riser/down-comer	N/A	N/A	N/A
	<b>B</b>	Number of hydrants per floor	N/A	N/A	N/A
	<b>C</b>	Hose box	N/A	N/A	N/A
<b>12.</b>	<b>Yard Hydrants:</b>				
	<b>A</b>	Total number of hydrants	N/A	N/A	N/A
	<b>B</b>	Hose box	N/A	N/A	N/A
<b>13.</b>	<b>Pumping Arrangements:</b>				
<b>1</b>	<b>Ground level</b>				
	<b>A</b>	Discharge of main pump	N/A	N/A	N/A
	<b>B</b>	Head of main pump	N/A	N/A	N/A
	<b>C</b>	Number of main pumps	N/A	N/A	N/A
	<b>D</b>	Jockey pump out put	N/A	N/A	N/A
	<b>E</b>	Jockey pump head	N/A	N/A	N/A
	<b>F</b>	Standby pump out put	N/A	N/A	N/A
	<b>G</b>	Standby pump head	N/A	N/A	N/A
	<b>H</b>	Auto starting /manual stopping	N/A	N/A	N/A
	<b>I</b>	Pump house access	N/A	N/A	N/A
<b>2</b>	<b>Terrace Level</b>				
	<b>A</b>	Discharge of pump	N/A	N/A	N/A
	<b>B</b>	Head of the pump	N/A	N/A	N/A
	<b>C</b>	Power supply	N/A	N/A	N/A
	<b>D</b>	Auto starting of pump	N/A	N/A	N/A



<b>14. Captive Water Storage for Fire Fighting:</b>				
A	Underground tank capacity	N/A	N/A	N/A
B	Draw-off connection	N/A	N/A	N/A
C	Fire service inlet	N/A	N/A	N/A
D	Access to tank	N/A	N/A	N/A
E	Overhead tank capacity	N/A	N/A	N/A
<b>15. Exit Signage:</b>		N/A	N/A	N/A
<b>16. Provision of Lifts:</b>				
A	Pressurization of lift shaft	N/A	N/A	N/A
B	Pressurization of lift lobby	N/A	N/A	N/A
C	Communication in lift car	N/A	N/A	N/A
D	Firemen's grounding switch	N/A	N/A	N/A
E	Lift signage	N/A	N/A	N/A
<b>17. Standby Power Supply:</b>		NA	N/A	N/A
<b>18. Refuge Area:</b>				
A	Total area	N/A	N/A	N/A
B	Location	N/A	N/A	N/A
<b>19. Fire Control Room:</b>				
A	Detector system panel	N/A	N/A	N/A
B	Flow switch panel	N/A	N/A	N/A
C	PA system panel	N/A	N/A	N/A
D	Battery backup	N/A	N/A	N/A
E	Building floor plans	N/A	N/A	N/A
<b>20. Special Fire Protection systems for protection of special Risks, if any:</b>		NA	N/A	N/A

The fire protection system was randomly checked and tested and was found functional at the time of inspection.

Keeping in view of the deemed compliance of minimum standards on fire prevention and fire safety measures as required under the Rules the Fire Safety Certificate issued vide letter no. F6/DFS/MS/School/2022/NDZ/428 dated 19/04/2022 under the Circular no F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01/03/2011 is recommended to be renewed.



Signature of the Inspecting Officer  
Name: - Yashwant Singh Meena  
Designation: - ADO/Laxmi Nagar

D.O/EAST

DFA please

Dy C/O (NDZ)

C.F.O.

K.V.P. Appraisal  
19/08/25 19.8.2025

19/8/2025

Principal Director

CFO to D.S.

ADD (L)

P.T.O

CFO

20/8/2025