

C32

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE

NEW DELHI- 110001

No.F6/DFS/MS/School/2025/SZ/ 942

Dated: 01/08/2025

FIRE SAFETY CERTIFICATE

Certified that the Govt. Sarvodaya Bal Vidyalaya No-2 at Tilak Nagar, New Delhi-110018, having two blocks namely- New block comprised of ground plus three upper floors and Old block comprised of ground plus two upper floors, owned/occupied by Govt. Sarvodaya Bal Vidyalaya, was issued FSC by this department vide letter No. F.6/DFS/MS/School/2021/SZ/426 dated 02.07.2021 (for new block) & letter No. F.6/DFS/MS/School/2015/SZ/1666 dated 14.09.2015 (for old block). The School building was re- inspected by the officer concerned of this department on dated 10.07.2025 in the presence of Principal, and found that the School building have deemed complied the fire prevention and fire safety requirements in accordance with Rule-33 of the Delhi Fire Service Rules, 2010 and that the building/ premises is fit for occupancy class "Educational Building" w.e.f 01/08/2025 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule-38 of the Delhi Fire Service Rules, 2010 printed as below.

Issued on 01/08/2025 at New Delhi.


 (Virendra Singh)
 Chief Fire Officer
 Delhi Fire Service

Copy to:-

1. Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi- 110054.
2. The Principal, Govt. Sarvodaya Bal Vidyalaya No. 2, at Tilak Nagar, New Delhi-110018.

Conditions for the validity of fire safety certificate: -

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

N/20

INSPECTION REPORT

1. Name & address of the building : Sarvodaya Bal Vidyalaya No-2, Tilak Nagar, New Delhi-110018.
2. Building is composition : having two blocks namely New Block comprised of G+3 upper floors & Old Block comprised of G+2 upper floors (Old blk of GF demolished by PWD & Old blk ground plus one upper floor is declared unsafe).
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of Previous NOC : F.6/DFS/MS/School/2021/SZ/426 dated 02.07.2021 (for new block) & F.6/DFS/MS/School/2015/SZ/1666 dated 14.09.2015 (for old block)
6. Fire Safety direction letter No : N/A
7. Date of Inspection : 10.07.2025
8. Name of the Inspecting Officers : ADO R.K. YADAV
9. Name of the designation of Officer from the building side : Principal
10. Year of Construction : 2020
11. Applicant's letter No : Nil, dated 02.07.2024

S.No.	Minimum Standards on fire prevention and fire safety requirements U/R 33	NBC Requirement	Provided at Site	Remarks MR/NMR
1	Access to building			
	Road width	6 m	06 m	MR
	Gate width	4.5 m	05 m	MR
	Width of internal road	N.A.	N.A.	N.A.
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	Upper Floor	02 no.	New blk- 02 nos. Old blk- 02 nos.	MR
	Basement	N.A.	N.A.	N.A.
	B. Width of Staircases			
	Upper Floor	N.A.	N.A.	N.A.
	Basement	1.50 m	New blk- 1.80 m each Old blk- 1.60 m each	MR
	c. Protection of exits			
	Fire check door	N.A.	N.A.	N.A.
	Pressurization	N.A.	N.A.	N.A.
	e. No. of continuous staircases to terrace	02 no.	02 no.	MR
	g. Width of Corridor	1.50 m	New blk- 1.60 m Old blk- 2.20 m	MR
	h. Door Size	1.20 m	New blk- 1.30m Old blk- 1.0 m (old case)	MR
3	Compartmentation.			
	Fire check door	N.A.	N.A.	N.A.
	Sealing of electrical shafts	N.A.	N.A.	N.A.
	Fire rating of shaft door	N.A.	N.A.	N.A.
	Water curtain	N.A.	N.A.	N.A.
	Fire Dampers	N.A.	N.A.	N.A.
4	Smoke Management System.			
	Basement	N.A.	N.A.	N.A.
	Upper floor	Required	Natural Ventilation	MR

N/21

5.	Fire Extinguisher			
	Total numbers	15 Nos.	20 Nos.	MR
	types	CO ₂ & ABC	CO ₂ & ABC	MR
	IS marking	ISI marked	ISI marked	MR
6	First-aid-Hose Reels.			
	Total numbers of each floor	02 Nos. each blk	Provided	MR
	Length of hose reel hose	30 m	Provided	MR
	Nozzle diameter	05 mm	Provided	MR
7	Automatic fire detection and alarming system.			
	Type of detectors	N.A.	N.A.	N.A.
	Location of main panel	N.A.	N.A.	N.A.
	Location of repeater panel	N.A.	N.A.	N.A.
	Alternate source of power	N.A.	N.A.	N.A.
	Hooters	N.A.	N.A.	N.A.
8	MOEFA	N.A.	N.A.	N.A.
9	Public address System.	N.A.	N.A.	N.A.
10	Automatic Sprinkler System.			
	basement	N.A.	N.A.	N.A.
	upper floor	N.A.	N.A.	N.A.
	sprinkler above false ceiling	N.A.	N.A.	N.A.
11	Internal Hydrants			
	size of riser/down-comer	N.A.	N.A.	N.A.
	Number of hydrants per floor	N.A.	N.A.	N.A.
	Hose Box	N.A.	N.A.	N.A.
12	Yard Hydrants.			
	Total number of hydrants	N.A.	N.A.	N.A.
	Hose Box	N.A.	N.A.	N.A.
13	Pumping Arrangements.			
	• Ground Level	N.A.	N.A.	N.A.
	➤ Discharge of main Pump	N.A.	N.A.	N.A.
	➤ Head of Main Pump	N.A.	N.A.	N.A.
	➤ Number of main pumps	N.A.	N.A.	N.A.
	➤ Jockey pump out put	N.A.	N.A.	N.A.
	➤ Jockey pump head	N.A.	N.A.	N.A.
	➤ Standby pump out put	N.A.	N.A.	N.A.
	➤ Standby pump Head	N.A.	N.A.	N.A.
	➤ Auto Starting /Manual stopping	N.A.	N.A.	N.A.
	➤ Pump House Access	N.A.	N.A.	N.A.
	• Terrace Level	N.A.	N.A.	N.A.
	➤ Discharge of pump	N.A.	N.A.	N.A.
		450 LPM each blk	Provided	MR
		40 m	Provided	MR
	➤ Head of the Pump	Required	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting.			
	Underground tank capacity	N.A.	N.A.	N.A.
	Draw-off connection	N.A.	N.A.	N.A.
	Fire service inlet	N.A.	N.A.	N.A.
	Access to tank	N.A.	N.A.	N.A.
	Overhead Tank capacity	10,000 ltrs each blk	Provided	MR
15	Exit Signage.	Required	Provided	MR

N/22

16	Provision of Lifts.			
	Pressurization of Lift Shaft	N.A.	N.A.	N.A.
	Pressurization of Lift lobby	N.A.	N.A.	N.A.
	Communication in lift car	N.A.	N.A.	N.A.
	Firemen's grounding switch	N.A.	N.A.	N.A.
	Lift Signage	N.A.	N.A.	N.A.
17	Standby power supply	N.A.	N.A.	N.A.
18	Refuge Area.			
	Total area	N.A.	N.A.	N.A.
	Location	N.A.	N.A.	N.A.
19	Fire Control Room			
	Detector system panel	N.A.	N.A.	N.A.
	Flow switch panel	N.A.	N.A.	N.A.
	PA system panel	N.A.	N.A.	N.A.
	Batter backup	N.A.	N.A.	N.A.
	Building Floor Plans	N.A.	N.A.	N.A.
20	Special Fire Protection systems for protection of special Risks, if any:	N.A.	N.A.	N.A.

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection. The shortcomings issued by this department vide letter No. F.6/DFS/MS/School/SZ/2024/506 dated 07.08.2024 have been rectified.

Note: - The FSC issued by this department vide latter No. F.6/DFS/MS/School2015/SZ/1666 dated 14.09.2015 for old block building having three blocks namely A-block comprised of ground plus two upper floors still running now, B-Block comprised of ground and first floor declared unsafe by PWD & C-Block comprised of ground floor only found demolished. Now, school having Old Block comprised of ground plus two upper floors and New Block comprised of ground plus three upper floors (New block issued FSC by this department vide letter No. F.6/DFS/MS/School/2021/SZ/426 dated 02.07.2021).

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter No. F.6/DFS/MS/School/2021/SZ/426 dated 02.07.2021 (for new block) & letter No. F.6/DFS/MS/School/2015/SZ/1666 dated 14.09.2015 (for old block), renewal under rule, 37 of the Delhi Fire Service Rules, 2010 is recommended.

R. K. Yadav
Signature of the Inspecting Officer
Name: -R. K. Yadav
Designation: - ADO (JKP)

DO (South West)

Qd

14/7/25

CFO

15/7/2025

Director
15/7/2025

Adm/2025