

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**

75  
आजादी का  
अमृत महोत्सव

No. F6/DFS/MS/WZ/2025/ 411

Dated:- 19/05/2025

To,

The Principal,  
Govt. Sarvodaya Co-ed. Vidyalaya (ID-1617008),  
B-4, Paschim Vihar, New Delhi-110063.

**Subj.:- Regarding renewal of Fire Safety Certificate in respect of Govt. Sarvodaya Co-ed. Vidyalaya, located at B-4, Paschim Vihar, New Delhi-110063.**

Sir,

Please refer to your letter no SV/Coed/B-4/PV/2025-26/1085 dated 28/04/2025 received in this department through outdoor diary no. 1129 dated 29/04/2025, on the subject cited above. In this connection, it is to inform you that the above said school building was re-inspected by the officer concerned of this department on 15/05/2025 in the presence of Dr. Rakesh Kumar (HOS). However, the following shortcoming has been observed:-

1. Fire extinguishers found removed.

In view of the above shortcomings, the application for renewal of Fire safety Certificate cannot be considered at this stage & rejected. You are advised to rectify the above mentioned shortcoming under intimation to this department for taking further necessary action.

Yours faithfully,

(Atul Garg)  
Director

Copy to:-

1. The Director, Directorate of Education, GNCT of Delhi, Old Secretariat Delhi - 110054.