



d/40

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI- 110001

No. F6/DFS/MS/School/2025/SZ/ 702

Dated: 09/09/2025

To,

The Principal,
Govt. Sarvodaya Vidyalaya,
DESU Colony, Janakpuri, New Delhi- 58.

Sub: - Regarding renewal of "FSC" from fire safety point of view in r/o Govt. Sarvodaya Vidyalaya at DESU Colony, Janakpuri, New Delhi- 110078.

Sir,

Please refer to your letter No. GSV/DESU/JKP/2025-26/437 dated 26.07.2025, on the subject cited above. In this connection, it is to inform you that officer concerned of this department inspected the school building on dated 18.08.2025, to verify the fire safety arrangements in accordance with the rules. At the time of inspection Principal of the school was present and it was observed that the school building comprised of still ground plus three upper floors, and have following shortcomings: -

1. Electrical shaft not sealed properly.
2. Terrace fire pump of 900 LPM provided and found not functional in auto mode.
3. Exit signage's are found removed at some places.

In view of the above, renewal of 'Fire Safety Certificate' cannot be granted at this stage. You are requested to rectify the above-mentioned shortcomings under intimation to this department for taking further necessary action in this matter and running school in absence of requisite fire safety arrangements shall be at the risk & liability of the school management.

Yours faithfully


(Virendra Singh)
Chief Fire Officer

Copy to:-

1. Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054.

94-