

c/19

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/School/NDZ/2025/591

Dated: 14 07/2025

To

The Principal,
Govt. Sarvodaya Kanya Vidyalaya,
Gokulpur village, Delhi-110094.

Sub: Regarding Fire Safety Certificate in r/o Govt. Sarvodaya Kanya Vidyalaya (School ID-1104021), Gokulpur village, Delhi-110094.

Sir,

This has reference to your letter No. GSKV/GPV/2025/296 dated 28/06/2025 on the subject cited above. In this regard, it is to inform you that the premises was inspected by the officer concerned of this department on 08/07/2025 in the presence of Mrs. Karuna Sharma (Principal) to ascertain the availability and operability of the fire prevention and fire safety measures and observed that at present school is Ground Floor, 1st Floor, 2nd Floor & 3rd floor only. Fire safety measures were checked as per the rules and following shortcomings were observed.

1. Hose reel hose provided but found non-functional.
2. Fire Pump of capacity 450LPM provided on terrace but found non-functional.
3. Exit signage found removed.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected under sub rule (3) of Rule 37 of DFS Rules-2010. The occupancy of the building/premises in absence of requisite fire safety arrangement shall be at the risk and liability of the management. The Statutory Authority may take suitable necessary action as deemed fit.

In this regard as stipulated in sub-Rule 37 of DFS Rules, 2010 you may apply with a fresh application for renewal of fire safety certificate under sub-rule (2) on Form "J" with compliance of above shortcomings. The web links for DFS Act-2007 / Rules 2010 & Form "J" are as under :
http://www.delhi.gov.in/wps/wcm/connect/doit_fire/Fire/Home/Fire+Safety+Acts+and+Rules/
http://www.delhi.gov.in/wps/wcm/connect/doit_fire/Fire/Home/Forms

Yours faithfully

(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE

Copy to:-

The Director of Education, Govt. of NCT of Delhi, Old Secretariat, Delhi-11054.