

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/School/WZ/2025/894

Dated: 14/07/2025

FIRE SAFETY CERTIFICATE

Certified that the Govt. Sarvodaya Co-ed Vidyalaya, located at H-Block, Karampura, New Delhi-110015. (School ID-1516104), comprised of total 04 blocks, 03 blocks (ground + 01 & 1 block ground floor only) A, C & D block (ground + 01 upper floor & b block (ground floor only), owned/Occupied by Govt. Sarvodaya Co-ed Vidyalaya, was issued FSC vide letter No F6/DFS/MS/School/WZ/2022/761 dated 15/07/2022. The premises was re-inspected by the officer concerned by this department on 02/07/2025, in the presence of Dr. Jawahar Lal Sharma (H.O.S) and observed that all the fire prevention & fire safety arrangements provided in the premises found in good working condition. That the building/premises have deemed complied with fire prevention and fire safety requirements in accordance with the Circular No.F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01/03/2011 and found that the building / premises is fit for the occupancy class "Educational" Group B with effect from 14/07/2025.. for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010. Condition mentioned below.

Issued on 14/07/2025..... at New Delhi.

(Atul Garg)
Director

Copy to:

1. Director of Education, GNCT of NCT of Delhi, Old Secretariat.
2. The Principal, Govt. Sarvodaya Co-ed Vidyalaya, located at H-Block, Karampura, New Delhi-110015. (School ID-1516104). **Email ID:-1516104zone16@gmail.com.**

Conditions for the validity of FSC:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
8. Fire fighting system which is provided in the building should be working condition for children safety.

INSPECTION REPORT

1.	Name & address of the building	Govt. Sarvodaya Co-ed Vidyalaya, located at H-Block, Karampura, New Delhi-110015.(School ID-1516104)
2.	Type of Occupancy	Educational
3.	Type of Case	Renewal
4.	Details of previous NOC	F6/DFS/MS/School/WZ/2022/761 dated 15/07/2022.
5.	Fire Safety directives letter No	3298-3398 dated 01/03/2011
6.	Date of inspection	02/07/2025
7.	Name of the Inspecting Officers	Sarabjeet Singh ADO (MN)
8.	Name and designation of officers from the building side	Dr. Jawahar Lal Sharma (H.O.S)
9.	Year of Construction	1960, D-block in 2013 (As per prev. Insp. Report dated 29/06/2022)
10.	Applicant's letter No.	Outdoor dairy No.2415 dated 04/06/2025.

The said school building comprised of total 04 blocks, 03 blocks (ground + 01 & 1 block ground floor only) A, C & D block (ground + 01 upper floor & b block (ground floor only), was issued FSC vide letter no. F6/DFS/MS/School/WZ/2022/761 dated 15/07/2022.

S. No	Minimum Standards on fire prevention and fire safety U/R 33	As per Rule 35 (6) DFS Rule 2010	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	6 m	Provided	MR
	• Gate width	4.5 m	Provided	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	Required	Provided	MR old case
	• Upper Floors	NA	NA	NA
	• Basements			
	b. Width of staircases	1.5 m	A-BLK=2 x 1.63 m, C-BLK=1 x 1.45 m, D-BLK=1 x 1.54 m, C & D BLK are connected with each other through corridor	MR old case
	• Upper Floors			
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	One	NA
	d. No. of continuous staircases to terrace	1.5 m	Provided	MR
	e. Width of Corridor	1.0 m	Provided	MR
	f. Door Size			
3	Compartmentation.			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA
5	Fire Extinguishers			
	• Total numbers	22 nos.	29 Provided	MR
	• Types	CO ₂ , ABC type	Provided	MR
	• IS marking	ISI marked	Provided	MR

6	First-Aid Hose Reels.			
	• Total numbers on each floor	NA	Provided	NA
	• Length of hose reel hose	NA	Provided	NA
	• Nozzle diameter	NA	Provided	NA
7	Automatic fire detection and alarming system.			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8	MOEFA	NA	NA	NA
9	Public Address System.	NA	NA	NA
10	Automatic Sprinkler System.			
	• Basement	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants			
	• Size of riser/down-comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12	Yard Hydrants.			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13	Pumping Arrangements.			
	• Ground Level			
	➤ Discharge of main Pump	NA	NA	NA
	➤ Head of Main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey Pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/ Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	NA	2 x 450 LPM Provided	NA
	➤ Head of the pump	NA	40 m Provided	NA
	➤ Power Supply	NA	Provided	NA
	➤ Auto Starting of pump	NA	Provided	NA
14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity		10,000 ltrs Provided	MR
15	Exit Signage.	NA	NA	NA

Provision of Lifts

	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17	Standby power supply	NA	NA	NA
18	Refuge Area.			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19	Fire Control Room			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Battery backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the rules, the NOC vide letter no F6/DFS/MS/School/WZ/2022/761 dated 15/07/2022, renewal under the rule 35 of the Delhi Fire Service rules 2010 is recommended.

258/ADO/MN
04/07/2025

24/12/2022

07/7/2025

Signature of the Inspecting Officer
Sarabjeet Singh ADO (MN)

DCFO/722/2022
Dated...2/9/2025

9/2
91/7/2025

Director
10/7/25

Sir, F.T is put up for your kind personal signature pls.
11/9/25