

c13

FORM 'H': FORM FOR ISSUING FIRE SAFETY CERTIFICATE

[See sub-rule (1) of rule 35]

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**


No.F.6/DFS/MS/School/2025/1015

Dated: 19/08/2025

**FIRE SAFETY CERTIFICATE**

Certified that the Govt. Sarvodaya Kanya Vidyalaya, New SPS Building (School ID-1104021) located at Gokulpur Village, New Delhi-110032 building comprised of Ground plus three upper Floors only owned / occupied by Govt. Sarvodaya Kanya Vidyalaya was issued FSC vide letter No. F6/DFS/MS/2022/NDZ/School/806 dated 29/07/2022. The school building was re-inspected by the officer concerned of this department on 25/07/2025 in presence of Mrs. Karuna Sharma (Principal) and observed that all the Fire Prevention and Fire Safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with rule 33 of the Delhi Fire Service Rule's 2010 and that the building / premises is fit for occupancy class "Educational" (Group-B) with effect from 19/08/2025 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rules, 2010.

**Issued on** 19/08/2025 **at New Delhi by.**

  
(VIRENDRA SINGH)  
CHIEF FIRE OFFICER.

Copy to :-

1. Principal, Govt. Sarvodaya Kanya Vidyalaya, (School ID-1104021) located at Gokulpur Village, New Delhi-110032.
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, Delhi-110054.

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangement provided there in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non-functional fire safety measure shall be at the responsibility of the management.
3. The trained firefighting staff should be available round the clock.
4. Any deviation with regard to the construction etc. shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [WWW.dfs.Delhigovt.nic.in](http://WWW.dfs.Delhigovt.nic.in)

# INSPECTION REPORT

1. Name & address of the building: Govt. Sarvodaya Kanya Vidyalaya (School ID-1104021), Gokulpur village, Delhi-110094.
2. Type of Occupancy : Educational, Group-B (School)
3. Building Comprised of : Ground plus three upper floors.
4. Type of Case : Renewal
5. Details of previous NOC No. F6/DFS/MS/2022/NDZ/School/809 dated 29/07/2022
6. Fire Safety directives Letter No. : NBC (Part-IV)
7. Date of inspection : 25/07/2025
8. Name of the Inspecting Officer : A.K. Jaiswal (D.O.)
9. Name and designation of Officer from the building side : Mrs. Karuna Sharma (Principal)
10. Year of Construction : 2022
11. Applicant's letter No. : GSKV/GVP/2025/376 Dated 15/07/2025

S No	Minimum standards on fire prevention and fire safety U/R 33	NBC (Part-IV) Requirement	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	06 m	06 m	MR
	• Gate width	4.50 m	4.50 m	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	3	3	MR
	• Basements	NA	NA	NA
	Width of staircases			
	• Upper floors	1.50m	1.80m x 3	MR
	• Basements	NA	NA	NA
	Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	b. No of continuous staircase to terrace	1	3	MR
	c. Width Of Corridor	1.50 m	1.50 m	MR
	d. Door Size	01 m	01 m x 2	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	Natural Ventilation	Natural Ventilation	MR
5.	Fire Extinguishers			
	• Total numbers	10 Nos	20 Nos	MR
	• Types	ABC /Co2	Provided	MR
	• ISI marking	ISI Marked	Provided	MR



6.	First – Aid Hose Reels			
	• Total numbers on each floor	03 no.	Provided	MR
	• Length of hose reel hose	30m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detector	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants			
	• Size of riser/down- comer	NA	100mm	NA
	• Number of hydrants per floor	NA	2	NA
	• Hose Box	NA	2	NA
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements			
	• Ground Level			
	• Discharge of main pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Staring/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	450 LPM	Provided	MR
	➤ Head of the pump	40 mtr	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for fire fighting			
	• Under ground tank capacity	NA	NA	NA
	➤ Draw of connection	NA	NA	NA
	➤ Fire service inlet	NA	Provided	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	10,000 Ltr	10,000 Ltr	MR

15	Exit Signage	Required	Provided	MR -
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

**Note:-** Shortcomings issued by this department vide letter No F6/DFS/MS/School/NDZ/2025/591 dated 14/07/2025 have been complied.

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the **NOC issued** vide letter No F6/DFS/MS/2022/NDZ/School/809 dated 29/07/2022 **renewal** under rule 35 of the Delhi Fire Service rules 2010 is recommended.

*Ashok*  
31-7-2025  
Signature of the Inspecting Officer  
Name : Ashok Kumar Jaiswal  
Designation: D.O. (East)

Dy. C.F.O. (NDZ)

*CFO*

*Principal Director*

*DO (East)*

*21/7/25*  
*02/08/25*

*11/08/2025*

*CFO to Jaiswal*

*CFO*

*14/8/2025*

*11/08/25*