GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001



a La DES/MS/2025/School/WZ/ 754

Dated: 09/06/2025

FIRE SAFETY CERTIFICATE

Certified that the Govt. Sarvodaya Kanya Vidhyalaya, H- Block, Sultanpuri, Delhi10036. (School ID-1412029) comprised of 02 blocks, Ground + 03 upper floors, has already been
and ESC by this department vide letter No. F.6/DFS/MS/2017/772 dated 30.05.2017 for old
10036. F.6/DFS/MS/School/WZ/2022/488 dated 05.05.2022 for new block. The premises was re10036 by the officer concerned of this department on 22.05.2025 in the presence of Mrs. Anita
10036 (Principal) and found that the said building have deemed complied with the fire prevention
10036 the safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and
10036 the premises fit for occupancy class Group B Educational with effect from 69 66 2025
10036 the premises fit for occupancy class Group B Educational with effect from 69 66 2025
10036 the premises fit for occupancy class Group B Educational with effect from 69 66 2025
10036 the premises fit for occupancy class Group B Educational with effect from 69 66 2025
10036 the premises fit for occupancy class Group B Educational with effect from 69 66 2025
10036 the premises fit for occupancy class Group B Educational with effect from 69 66 2025
10036 the premises fit for occupancy class Group B Educational with effect from 69 66 2025
10036 the premises fit for occupancy class Group B Educational with effect from 69 66 2025
10036 the fit for occupancy class Group B Educational with effect from 69 66 2025
10036 the fit for occupancy class Group B Educational with effect from 69 66 2025
10036 the fit for occupancy class Group B Educational with effect from 69 66 2025
10036 the fit for occupancy class Group B Educational with effect from 69 66 2025
10036 the fit for occupancy class Group B Educational with effect from 69 66 2025
10036 the fit for occupancy class Group B Educational with effect from 69 66 2025
10036 the fit for occupancy class Group B Educational with effect from 69 66 2025
10036 the fit for occupancy class Group B Educational with effect from 69 66 2025
10036 the fit for

Land on 09 06 2025 at New Delhi

p., to, 4

(Virendra Singh)
Chief Fire Officer

The Director, Education, Government of N.C.T of Delhi. Old Sect. Delhi - 54.

The Principal, Govt. Sarvodaya Kanya Vidhyalaya, H- Block, Sultanpuri, Delhi-110086. (School ID-1412029).

Conditions for the validity of Fire Safety Certificate:

- If the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
- Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.

The trained fire fighting staff should be available round the clock.

Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.

This certificate cannot be treated in any case for regularizations of unauthorized construction.

The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Lorm J [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on

- If the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.
- www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/

www.delhi.gov.in/wps/wcm/connect/doit fire/FIRE/Home/Forms

INSPECTION REPORT

Name & address of the building: Sarvodaya Kanya Vidhyalaya, H- Block, Sultanpuri, Delhi-110086

: Educational (School Id-1412029)

2. Type of Occupancy
3. Type of Case
4. Details of Previous NOC : Renewal (02 blocks, Ground + 03 upper floors) : F.6/DFS/MS/2017/772 dated 30.05.2017 for Old Blk &

F.6/DFS/MS/School/WZ/2022/488 dated 05.05.2022 for New Blk

5. Fire Safety directives letter No : NBC Part-IV 6. Date of inspection : 22.05.2025

7. Name of Inspecting Officer : A.K.Sharma ADO(Rohini)

8. Name and designation of officers

From the building side : Mrs. Anita Malik (Principal)

		Construction : 2017 & 2021 ht's letter No. : Online e-mail	dated 05.05.2025		
10. S. No.		um Standards on fire prevention	NBC	I I UVIUCU at Site	Remarks
9. 110.		e safety U/R 33	Requirement		MR/NMR
	B 2 22 1 1 Sec. (7.11)	to building			1 M
	•	Road width	6.0m	12m	MR
		Gate width	4.5m	Provided	MR
	•	Width of internal road	-NA-	-NA-	-NA-
2.	Numb	er, Width, Type & Arrangement of Ex	cits	1	
2.		mber of staircases		01171 1 02	MR
		Upper Floors	Old Block-02	Old Block-03 New Block-02 + 01 ramp	
		Эрри	New Block-02	CAN WINDOWS	-NA-
	•	Basements	-NA-	-NA-	-IVA-
	b. Width of staircases				MD
			Old Block-1.5m	Old Block-2 x 1.7m	MR
	•	Upper Floor	New Block-1.5m	New Block-2 x 1.5m &	MR
			27.4	1.6m ramp -NA-	-NA-
		Basements	-NA-	-NA-	
	c. Pro	tection of exits		NA	-NA-
	Fire	check door	-NA-	-NA-	-NA-
	•	Pressurization	-NA-	-NA-	MR
	d.	No. of continuous staircases to terrace	Old Block-01	Old Block-02nos. New Block-02nos.	MR
			New Block-02 Old Block-R	Old Block-Provided	MR
	e. W	dth of Corridor	New Block-1.5m	New Block-1.7m	MR
		G.	-NA-	-NA-	-NA-
		oor Size	-NA-		
3.	Comp	artmentation Fire check door	-NA-	-NA-	-NA-
		Sealing of electrical shafts	-NA-	-NA-	-NA-
	•	Fire Rating of shaft door	-NA-	-NA-	-NA-
		Water Curtain	-NA-	-NA-	-NA-
		Fire Dampers	-NA-	-NA-	-NA-
4.	Smok	e Management System		1000000	
	•	Basements	-NA-	-NA-	-NA-
	•	Upper floors	12 a/c per hour	Natural ventilation	MR
5.	Fire F	xtinguishers			
	•	Total numbers	Old Block-14	Old Block-Provided	MR
			New Block-45	New Block- Provided	MR
	•	Types	ABC/CO2	ABC/CO2	MR
	•	IS marking	ISI marked	Yes	MR
6.	First-	Aid Hose Reels			

16.	Provision of Lifts. Pressurization of Lift Shaft	NA	NA		NA	
	Total Control					
15.	Exit Signage.	Required	Provided	1	MR	
		New Block-10,000ltr	New Block-10,000ltr		MR	
		Old Block-10,000ltr	Old Block-10,000ltr	1	MR	
	> Access to tank	-NA-	-NA-		NA-	
	> Fire service inlet	-NA-	-NA-		NA-	
	> Draw-off connection	-NA-	-NA-	_	NA-	
	Underground tank capacity	-NA-	-NA-	-	NA-	
14.	Captive Water Storage for fire fighting	Required	Tiovided		IVIIV	
	> Auto Starting of pump	Required	Provided	-	MR	
	➢ Head of the pump➢ Power Supply	40m Required	40m Provided		MR MR	
	➤ Head of the pump	New Block-450lpm		Jipm	MR	
	➤ Discharge of pump	Old Block-450lpm	at the commence of the second		MR	
	Terrace level		-MA		177.	
	➤ Pump House Access	-NA-	-NA-		-NA-	
	➤ Auto Starting/Manual Stopping	-NA-	-NA-		-NA-	
	> Standby Pump Head	-NA-	-NA-		-NA-	
	> Standby Pump out put	-NA-	-NA-		-NA-	
	> Jockey pump head	-NA-	-NA-		-NA	
*	> Jockey Pump out put	-NA-	-NA-		-NA	
	Head of Main pumpNumber of main pumps	-NA-	-NA-		-NA	
	1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1	-NA-	-NA-		-NA	
	➤ Discharge of main Pump	-NA-	-NA-		NT.4	
	Ground Level					
13.	Pumping Arrangements	-NA-	-NA-		-NA-	
	 Total number of hydrants Hose Box 	-NA-	-NA-		-NA-	
12.	Yard Hydrants Total number of hydrants					
12	Hose Box	-NA-	-NA-		-NA-	
	Number of hydrants per floor	-NA-	-NA-		-NA-	
	Size of riser/down-comer	-NA-	Provided old blk		-NA-	
11.	Internal Hydrants			+	11/1-	
	Sprinkler above false ceiling	-NA-	-NA-	+	-NA-	
	Ground & Upper Floors	-NA-	-NA-	-	-NA-	
	Basement	-NA-	-NA-	+	-NA-	
10.	Automatic Sprinkler System			+	11/1	
9.	Public Address System	-NA-	-NA-	-	-NA	
8.	MOEFA	-NA-	-NA-		-NA	
	- Hootels Location	-NA-	-NA-		-NA	
	Alternate source of power Hooters' Location	-NA-	-NA-	-	-NA	
	Location of Repeater Panel	-NA-	-NA-		-NA	
	 Location of Main Panel 	-NA-	-NA-		-NA	
	 Type of detectors 	-NA-	-NA-		-NA	
7.	Automatic fire detection and alarming system					
	 Nozzle diameter 	5m	Provided		M M	
	 Length of hose reel hose 	30mm	Provided	vided	M	
	San Guell Hoof	New Block-			M	
	 Total numbers on each floor 	Old Block-0	Old Block-Prov	ided		

Y	• Pressurization of Lift lobby	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
	Communication In lift Car	-NA-	-NA-	-NA-
	Fireman's Grounding Switch	-NA-	-NA-	-NA-
	• Lift Signage	-NA-	-NA-	-NA-
_	Standby power supply	- TWA		
_	Refuge Area.	-NA-	-NA-	-NA-
	> Total Area	-NA-	-NA-	-NA-
	> Location	-141		
_	Fire Control Room	-NA-	-NA-	-NA-
	Detector System Panel	-NA-	-NA-	-NA-
	 Flow Switch Panel PA System Panel Battery backup 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
	Building Floor Plans	-NA-	-NA-	-NA-
).	Special Fire Protection System for Protection of special Risks, if any:	2 = 2	- tosted/ checked	randomly an

Accordingly, the fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.

Keeping in view the satisfactory compliance of the minimum standards on fire prevention and fire safety required as stipulated in NBC Part-4, and removal of shortcomings issued vide letter no. 551 dated 07.10.2021 for old block, the FSC issued vide letter no. F.6/DFS/MS/2017/772 dated 30.05.2017 for old block & F.6/DFS/MS/School/WZ/2022/488 dated 05.05.2022 for new block, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended

Signature of the Inspecting Officer
Name Ajay Kumar Sharma
Designation ADO (Rohini)

SENIO V

23/05/202

My es (w2)

CFD/ Mugh

Dheeta

(Rohimi)

Director (FO 4 61) sons

for letter to pur up for Ican plear.

Chuy

Mscell