



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

75
आज़ादी का
अमृत महोत्सव

No. F6/DFS/MS/School/WZ/2025/ 829

Dated: 25/06/2025

FIRE SAFETY CERTIFICATE

Certified that the Govt. Sarvodaya Kanya Vidyalaya No.- 2, located at Khyala (New Building), New Delhi- 110018. (School ID -1514013), comprised of ground + 03 upper floors, owned/Occupied by Govt. Sarvodaya Kanya Vidyalaya No.- 2 khayla, was issued FSC vide letter No F6/DFS/MS/School/WZ/2022/28 dated 12/01/2022. The premises was re - inspected by the officer concerned by this department on 11/06/2025, in the presence of Smt. Monika Budgujar (Principal) and observed that all the fire prevention & fire safety arrangements provided in the premises found in good working condition. That the building/premises have deemed complied with fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire service Rules 2010 and found that the building / premises is fit for the occupancy class "Educational" Group B with effect from 25/06/2025 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010. Condition mentioned below.

Issued on 25/06/2025 at New Delhi.

(Atul Garg)
Director
Delhi Fire service

Copy to:-

1. The Director, Directorate of Education, Old Secretariat Delhi.
2. The Principal Govt. Sarvodaya Kanya Vidyalaya No.- 2, located at Khyala (New Building), New Delhi- 110018. Email ID- skvno.2khayala@gmail.com

Conditions for the validity of FSC:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.

INSPECTION REPORT

1.	Name & address of the building	Govt. Sarvodaya Kanya Vidyalaya No.- 2, located at Khyala (New Building), New Delhi- 110018. (School ID - 1514013)
2.	Type of Occupancy	Educational (Ground + 03 Upper Floor)
3.	Type of Case	Renewal
4.	Details of previous NOC	F6/DFS/MS/School/WZ/2022/28 dated 12/01/2022
5.	Fire Safety directives letter No	Nil
6.	Date of inspection	11/06/2025
7.	Name of the Inspecting Officers	Sarabjeet Singh ADO (MN)
8.	Name and designation of officers from the building side	Smt. Monika Budgujar (Principal)
9.	Year of Construction	2021 (As per previous Inspection Report dated 30/12/2021)
10.	Applicant's letter No.	Email dated 16/01/2025

The said school building comprised of Ground + 03 Upper Floor, was issued FSC vide letter no. F6/DFS/MS/School/WZ/2022/28 dated 12/01/2022.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	As per Rule 35 (6) DFS Rule 2010	Provided at site	Remarks MR/NMR
1	Access to building			MR
	• Road width	06m	Provided	MR
	• Gate width	4.5m	Provided	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			MR
	• Upper Floors	02	02 Provided	NA
	• Basements	NA	NA	NA
	b. Width of staircases			MR
	• Upper Floors	1.5m each	3X1.5m Provided	NA
	• Basements	NA	NA	NA
	c. Protection of exits			NA
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	01	Provided	MR
	e. Width of Corridor	1.5m	NA	NA
	f. Door Size	2 X 1.20 mtr	Provided	MR
3	Compartmentation.			NA
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			NA
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA
5	Fire Extinguishers			MR
	• Total numbers	12 nos.	Provided	MR
	• Types	CO ₂ , ABC type	Provided	MR
	• IS marking	ISI marked	Provided	MR
6	First-Aid Hose Reels.			MR
	• Total numbers on each floor	01	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR

7	Automatic fire detection and alarming system.			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8	MOEFA			
9	Public Address System.			
10	Automatic Sprinkler System.			
	• Basement	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants			
	• Size of riser/down-comer	NA	Provided	NA
	• Number of hydrants per floor	NA	Provided	NA
	• Hose Box	NA	Provided	NA
12	Yard Hydrants.			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13	Pumping Arrangements.			
	• Ground Level			
	➤ Discharge of main Pump	NA	NA	NA
	➤ Head of Main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey Pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/ Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	450LPM	Provided	MR
	➤ Head of the pump	40 m	Provided	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	Provided	MR
	➤ Access to tank	NA	Provided	MR
	• Overhead Tank capacity	10,000 ltrs	Provided	MR
15	Exit Signage.			
		Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17	Standby power supply			
		NA	NA	NA
18	Refuge Area.			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA

Fire Control Room				
19	<ul style="list-style-type: none"> Detector System Panel Flow Switch Panel PA System Panel Battery backup Building Floor Plans 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	NA

The Fire Protection system provided in the building were checked and found functional at the time of inspection. The shortcomings issued by this department vide letter No F6/DFS/MS/School/WZ/2025/109 dated 14/02/2025, have been complied by the management of school.

Keeping in view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the rules, the NOC vide letter no F6/DFS/MS/School/WZ/2022/28 dated 12/01/2022 renewal under the rule 35 of the Delhi Fire Service rules 2010 is recommended.

By CPO (PPW)

[Signature]
18/6/2025
Signature of the Inspecting Officer
Sarabjeet Singh ADO (MN)

[Signature]
18/6/25

CFO / [Signature]
20/6/2025

Director

[Signature]
20/6/25

[Signature]
20/6/25

Sir, F-7 is put up for your kind personal & signature please.

Director

[Signature]
23/6/2025