



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/School/WZ/2025/993

Dated:- 13/08/2025

FIRE SAFETY CERTIFICATE

Certified that the Govt. Sarvodaya Kanya Vidyalaya (ID-1617014), Located at Mundka, Delhi-110041, comprised of 03 Blocks, Old building=Ground + 02 Upper floors, One M. P. Hall & New Building, Block-A& B=Ground + 03 Upper Floors, was issued Fire Safety Certificate by this department Vide Letter No. F6/DFS/MS/School/WZ/2022/816 dated 29/07/2022. The said premise was re-inspected by the officer concerned of this department on 26/07/2025 in the presence of Sh. Rajbir Malik (Estate Manager) and found that the premises/building have deemed complied with the fire prevention and fire safety requirements in accordance D.O.E., Cr. No. 3298-3398 dated 01/03/2011 & NBC (Part-IV) and that the premises/building is fit for occupancy class "Educational Building" Group B with effect from 13/08/2025 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 13/08/2025 at New Delhi by.


12/8/2025
Virendra Singh
Chief Fire Officer

Copy to: -

1. The Director, Directorate of Education Old Secretariat, Delhi – 110054.
2. The Principal, Govt. Sarvodaya Vidyalaya (ID-1617014), Mundka, Delhi-110041.

Conditions for validity of fire safety certificate:-

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner /occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.
8. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37) along with copy of the certificate, six months prior to its expiry.

INSPECTION REPORT

1. Name and address of the building: Govt. Sarvodaya Kanya Vidyalaya (ID-1617041)
Located at Mundka, New Delhi-110041
2. Type of Occupancy : Educational, 03 blocks (Old Building=Ground + 02 Upper floors, Two New Block, BL-A & B=Ground + 03 Upper floors & one M.P. Hall)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/School/WZ/2022/816 dated 29/07/2022
5. Fire Safety directives Letter No. : Cr. No.3298-3398 dated 01-03-2011/NBC Part-VI
6. Date of inspection : 26/07/2025
7. Name of the Inspecting Officer : Aman Kumar Lathar, ADO (JWP)
8. Name and designation of Officer
from the building side : Sh. Rajbir Malik (Estate manager)
9. Year of Construction : Before 2011 (Old building) & 2017 (New building)
10. Applicant's letter No. : Form 'K' dated 02/07/2025

S No	Minimum standards on fire prevention and fire safety U/R 33	D.O.E. Circular No. 3298-3398 Dated 01.03.2011/as per earlier FSC issued dated 29/07/2022	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	06 m	Provided	MR
	• Gate width	4.5 m	Direct accessible form road	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases	02 nos. each block	Provided	MR
	• Upper floors	NA	NA	NA
	• Basements			
	b. Width of staircases	1.5 m	Old Block- 1.7 m & 1.68 m	MR
	• Upper floors	each block	New Block A & B- 1.8 m x 2	
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	01	Provided	MR
	e. Width Of Corridor	1.5 m	Provided	MR
	f. Door Size	1 m	Provided	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	Required	Natural Ventilation	MR

5.	Fire Extinguishers			
	• Total numbers	32 nos.	Provided	MR
	• Types	ABC & CO ₂	Provided	MR
	• IS marking	ISI marked	Provided	MR
6.	First – Aid Hose Reels			
	• Total numbers on each floor	02 nos. each block	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	Provided	NA
10.	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants:			
	• Size of riser/down- comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements:			
	• Ground Level			
	• Discharge of main pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Staring/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	450 lpm each block	Provided	MR
	➤ Head of the pump	30 m	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for firefighting:			
	• Underground tank capacity	NA	NA	NA
	➤ Draw off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	10,000 ltrs. each block	Provided	MR
15.	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA

17	Standby power supply	NA	NA	NA
18	Refuge Area.			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19	Fire Control Room			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Battery backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	NA

Fire protection systems provided in the building were checked and found functional at the time of inspection.

Note:- M.P. Hall with area 476 sq. meters is having 02 doors of width 1.90 m & 03 doors of 1.5 m having no fixed sitting arrangements. Hall is protected by hose reel on both side and fire extinguisher.

In view of the deemed compliance of minimum standards of fire prevention and fire safety requirements under the rules, renewal of Fire Safety Certificate issued vide letter no. F6/DFS/MS/School/WZ/2022/816 dated 29/07/2022, is **recommended** under Rule 37 of the Delhi Fire Service Rules, 2010 under DFS Act 2007.

Accordingly DFA is prepared & put up for approval please.

[Signature]
28/07/25
Aman Kumar Lathar
ADO (JWP)

[Signature]
DCFO/WZ

[Signature]
31/7/25

[Signature]
CFO

[Signature]
4/8/2025

[Signature]
Principal Director

[Signature]
CFO to Secy.

[Signature]
CFO

ADO (JWP)

Sir, R.I. letter is put up for your signature pl.

[Signature]
CFO

[Signature]
4/8/2025

[Signature]
intoler
28/07/25

DCFO/...226/WZ
Dated...31/7/2025